

TYNDP 2020 ENTSO-E dataset specification

October 2020

To satisfy growing stakeholder expectations for transparency on grid and market data, ENTSO-E aims to have a systematized approach towards the availability of fit-for-purpose quality data to third parties. The Board adopted on 23 November 2017 a new Data Policy, aiming to increase data quality and data re-use with the ultimate objective of ensuring, when relevant, open data license. Increased transparency is also one of strategic priority of ENTSO-E Roadmap 2018 – 2022, approved by the Assembly at its 21 February 2018 meeting. ENTSO-E is implementing the Data Policy first and foremost on the Transparency Platform, and will progressively extend it to other relevant data projects in ENTSO-E.

At the 28 June 2018, the Assembly and Members approved a Memorandum of Understanding related to the Transparency Platform. This MoU complements the Transparency Regulation and guides the cooperation between the TSOs and ENTSO-E, as required by the Transparency Regulation, towards an increased transparency for TP end users, an increased quality of TP data, and a facilitation of TP data re-use.

According to ENTSO-E decision the data set will be provided in CGMES 2.4.15 format.

The purpose of the present document is to describe the content and capabilities of the ENTSO-E dataset created in 2020.

Revision History

Version	Date	Author	Summary of Changes	Changed Chapters
0.0	22/10/2020	WG DM		
0.01	05/03/2021	WG DM	Corrected balances, added notes	1, 3.2, 8

TABLE OF CONTENTS

1. Scope.....	3
2. Abbreviations	4
3. Starting data and IGM	4
3.1 Model inputs.....	4
3.2 Generation/ demand and country balance.....	5
4. IGM analysis	6
4.1 Model description	6
4.2 Model content	9
4.2.1 CGMES files	9
4.2.2 Classes used	9
4.2.3 Base voltages	10
4.2.4 Boundary used.....	12
4.3 Data quality checks.....	13
4.3.1 Generation Balance checks	13
4.3.2 Loading and voltage violations	13
4.3.3 Losses	15
5. Merged model analysis	17
5.1 Model content	17
5.1.1 AC Lines	23
5.1.2 PST.....	29
5.2 HVDC and external network connections location.....	29
6. Merged model specification.....	32
6.1 Load flow study	33
6.1.1 CE Synchronous area	33
6.1.2 Baltics Synchronous area.....	67
6.2 Contingency analysis	73
6.2.1 CE Synchronous area	73
6.2.2 Baltics Synchronous area.....	73
6.3 Short circuit study.....	74
6.4 Other studies.....	74
7. References.....	74
8. Notes	74

1. Scope

The Specification for the ENTSO-E data set is intended to facilitate the use and understanding of the NT2025_European model by third parties performing power system studies. The reference grid dataset is a European model, with generation and demand according to Market simulation in Scenario NT2025. The model is divided by synchronous areas: Continental Europe, Baltics, Great Britain and Ireland and Nordic TSOs. For TYNDP 2020 there are model available for Continental Europe and Baltics synchronous areas. The IGMs should be merged and solved for each synchronous area.




Figure.1

2. Abbreviations

BD	Boundary file
CE	Continental Europe
CGMES	Common Grid Model Exchange Standard
CIM	Common Information Model
HVDC	High Voltage Direct Current
IGM	Individual Grid Model
NMD	Network Modelling Database
NT	National Trends
NTC	Net Transfer Capacity
OHL	Overhead line
PATL	Permanent Admissible Transmission Line Loading
PEMMDB	Pan European Market Model Database.
PST	Phase Shifting Transformer
R	Resistance
RG	Regional group
RG CE	Regional Group Continental Europe
TP	Transparency Platform
TSO	Transmission System Operator
TYNDP	Ten Year Network Development Plan
X	Reactance

3. Starting data and IGM

The base for the TYNDP 2020 ENTSO-E Dataset is the market simulation for Scenario NT2025 and according to the generation types defined in PEMMDB.

3.1 Model inputs

The NT2025 market simulation provides the generation, demand and balances for each hour of the scenario time. For the grid model, a single hour is selected and the data for generation, demand, exchanges and balances is inserted in the grid model.

3.2 Generation/ demand and country balance

For the generation/ demand and cross border balance the following data were implemented in the models.

Continental Europe (CE):

		Installed power (MW)	<i>Generated Power (MW)</i>	Load (MW)	Balance (MW)
1	AL	2988.74	1429	1348	51
2	AT	28399.7	11169	11469	-417
3	BA	5050.7	3140	1725	1350
4	BE	25071.16	12504	11906	475
5	BG	10986.3	6018	5292	610
6	CH	24370	8877	8696.52	50
7	CZ	19094.6	11532	10246	1164
8	DE	283317	76180	76902	-2241
9	DK	13301.14	6391	6070	321
10	ES	130308.6	38429	35173	2455
11	FR	166760.5	77823	73461	2913
12	GR	31915	6952	6853	-43
13	HR	5637.15	1976	2191	-342
14	HU	11313.5	4529	5530	-1168
15	IT	128648	38583	46249	-8036
16	LU	2109	155	1191	-1044

17	ME	1944	454	535	-97
18	MK	2052.1	1189	1174	0
19	NL	42240.83	17363.54	16177	859
20	PL	46073.81	22818	25601	-3100
21	PT	25294.1	6538	6818	-373
22	RO	20391.66	9928	8282	1474
23	RS	10183.47	6506	5870	482
24	SI	4011.89	2484	2136	348
25	SK	7734	4054	4642	-615

Baltics:

		Installed power (MW)	<i>Generated Power (MW)</i>	Load (MW)	Balance
1	EE	2497	1292	1372	-33
2	LT	3403	772	1909	-1164
3	LV	2767	1263	1130	132

4. IGM analysis

4.1 Model description

The models submitted for 2025 Refgrid are aggregated bus branch models with the generation and load connected to the nearest High Voltage node.

For transmission lines rated voltages present in the model range from 110 kV to 750 kV.

All elements connected at 220 kV and above are modelled explicitly.

Representation of the non-radial 150 kV, 132 kV and 110 kV shall be represented at the 220-kV level.

Branches and substations of the network under the 220-kV voltage level shall not be represented in detail.

Loads shall be aggregated at the closest extra-high voltage (EHV) node to represent the actual loading on the connection point. Losses shall be considered. Embedded generation shall be represented as generation connected to the next EHV-HV node.

The step-up transformers are not usually represented in the model; however, it is not a mandatory requirement.

Requirement	Comment or additional specification	ENTSO-E dataset
Bus-branch model		✓
Reduced model 110- 750 kV Level with generation and load aggregated in the HV nodes.		✓
Generation types	Generation types according to CGMES classes: Thermal, Nuclear, Hydro, Wind, Generating unit (generic)	✓
Existing thermal generating units are present in the model		✓
Existing and planned units for other generating units are aggregated.		✓
Substations are usually represented as one busbar per substation. Retained switches are allowed to couple several bus bar sections.	See figure 2 Sample substation type 1 Figure 3 substation type 2	✓
All load flow models shall be submitted after a solution from a flat start with a mismatch tolerance of 1 MW or 1 MVAR per node and total mismatch less than 5 MVA.		✓
Models are checked for voltage violations.		✓
There shall be no overloaded elements in the load flow models prior to a contingency run and model assembling.	Valid for all IGMs	✓
Assembled models shall have solution with a mismatch tolerance of 1 MW or 1 Mvar per node and total mismatch less than 5 MVA.	Valid for the assembled models	✓
Controls present in the model are: <ul style="list-style-type: none"> • Voltage controllers • Power- Frequency control • Shunt controls 		✓
Voltage of nodes next to a tie-line are not in the following ranges: <ul style="list-style-type: none"> • for 380 (400) kV nodes: 405 kV – 415 kV • for 220 (225) kV nodes: 220 kV – 231 kV 		✓
Reactive transit flow on tie-lines for assembled models shall be lower than 50 Mvar for 380 (400) kV lines and 25 Mvar for 220 (225) kV lines considering the voltage difference is smaller than 1% between the ends of tie-lines. Therefore, individual models part of the assembled model shall target minimal reactive power exchange at boundary points (e.g. preferable close to zero Mvar).		✓

Active Power limits for generators Pmax, Pmin		✓
Reactive power capability limits as percentage of rated P	Limits in ENTSO-E dataset will be only Qmin, Qmax as a function of rated P.	✓
Thermal ratings AC lines		✓
HVDC lines	HVDC lines are represented as unconnected buses with equivalent injections.	✓

Figure 3.





Figure 4.



4.2 Model content

4.2.1 CGMES files

All TSOs have provided the CGMES profiles EQ, TP, SSH, SV. So, a solved model is provided.

4.2.2 Classes used

The CGMES classes used in the ENTSO-E dataset are the following:

- 1 ACLineSegment
- 2 BaseVoltage
- 3 Breaker
- 4 BusbarSection
- 5 ConformLoad
- 6 ConformLoadGroup
- 7 ConnectivityNode
- 8 ControlArea
- 9 ControlAreaGeneratingUnit
- 10 CurrentLimit
- 11 Disconnecter
- 12 EnergyConsumer
- 13 EquivalentBranch
- 14 EquivalentInjection
- 15 ExternalNetworkInjection
- 16 GeneratingUnit
- 17 GeographicalRegion
- 18 HydroGeneratingUnit
- 19 HydroPowerPlant
- 20 Junction
- 21 Line
- 22 LinearShuntCompensator
- 23 LoadBreakSwitch
- 24 LoadResponseCharacteristic
- 25 NonConformLoad
- 26 NonConformLoadGroup
- 27 NuclearGeneratingUnit
- 28 OperationalLimitSet
- 29 OperationalLimitType
- 30 PhaseTapChangerAsymmetrical
- 31 PhaseTapChangerSymmetrical
- 32 PhaseTapChangerTable
- 33 PhaseTapChangerTablePoint
- 34 PhaseTapChangerTabular
- 35 PowerTransformer
- 36 PowerTransformerEnd
- 37 RatioTapChanger
- 38 RegulatingControl
- 39 SeriesCompensator

- 40 StaticVarCompensator
- 41 SubGeographicalRegion
- 42 Substation
- 43 SvPowerFlow
- 44 SvShuntCompensatorSections
- 45 SvTapStep
- 46 SvVoltage
- 47 SynchronousMachine
- 48 TapChangerControl
- 49 Terminal
- 50 ThermalGeneratingUnit
- 51 TieFlow
- 52 TopologicalIsland
- 53 TopologicalNode
- 54 VoltageLevel
- 55 WindGeneratingUnit
- 56 EnergySchedulingType
- 57 FullModel

4.2.3 Base voltages

1	AC-0-4	AC-0-4	Base voltage defined by ENTSO-E 0.4 kV	AC-0-4	0.4
2	AC-10	AC-10	Base voltage defined by ENTSO-E 10 kV	AC-10	10
3	AC-10-25	AC-10-25	Base voltage 10-25 kV	AC-10-25	10.25
4	AC-10-5	AC-10-5	Base voltage defined by ENTSO-E 10.5 kV	AC-10-5	10.5
5	AC-11	AC-11	Base voltage defined by ENTSO-E 11 kV	AC-11	11
6	AC-11-5	AC-11-5	Base voltage defined by ENTSO-E 11.5 kV	AC-11-5	11.5
7	AC-110	AC-110	Base voltage defined by ENTSO-E 110 kV	AC-110	110
8	AC-115	AC-115	Base voltage defined by ENTSO-E 115 kV	AC-115	115
9	AC-12	AC-12	Base voltage defined by ENTSO-E 12 kV	AC-12	12
10	AC-120	AC-120	Base voltage defined by ENTSO-E 120 kV	AC-120	120
11	AC-124	AC-124	Base voltage defined by ENTSO-E 124 kV	AC-124	124
12	AC-125	AC-125	Base voltage defined by ENTSO-E 125 kV	AC-125	125
13	AC-13	AC-13	Base voltage 13 kV	AC-13	13
14	AC-13-8	AC-13-8	Base voltage defined by ENTSO-E 13.8 kV	AC-13-8	13.8
15	AC-130	AC-130	Base voltage 130 kV	AC-130	130
16	AC-132	AC-132	Base voltage defined by ENTSO-E 132 kV	AC-132	132
17	AC-135	AC-135	Base voltage defined by ENTSO-E 135 kV	AC-135	135
18	AC-14-4	AC-14-4	Base voltage defined by ENTSO-E 14.4 kV	AC-14-4	14.4
19	AC-15	AC-15	Base voltage defined by ENTSO-E 15 kV	AC-15	15
20	AC-15-5	AC-15-5	Base voltage 15.5 kV	AC-15-5	15.5
21	AC-15-75	AC-15-75	Base voltage defined by ENTSO-E 15.75 kV	AC-15-75	15.75
22	AC-150	AC-150	Base voltage defined by ENTSO-E 150 kV	AC-150	150

23	AC-154	AC-154	Base voltage defined by ENTSO-E 154 kV	AC-154	154
24	AC-16	AC-16	Base voltage defined by ENTSO-E 16 kV	AC-16	16
25	AC-165	AC-165	Base voltage defined by ENTSO-E 165 kV	AC-165	165
26	AC-17	AC-17	Base voltage 17 kV	AC-17	17
27	AC-18	AC-18	Base voltage 18 kV	AC-18	18
28	AC-19	AC-19	Base voltage 19 kV	AC-19	19
29	AC-19-5	AC-19-5	Base voltage 19.5 kV	AC-19-5	19.5
30	AC-193	AC-193	Base voltage defined by ENTSO-E 193 kV	AC-193	193
31	AC-20	AC-20	Base voltage defined by ENTSO-E 20 kV	AC-20	20
32	AC-200	AC-200	Base voltage defined by ENTSO-E 200 kV	AC-200	200
33	AC-21	AC-21	Base voltage defined by ENTSO-E 21 kV	AC-21	21
34	AC-22	AC-22	Base voltage 22 kV	AC-22	22
35	AC-220	AC-220	Base voltage defined by ENTSO-E 220 kV	AC-220	220
36	AC-225	AC-225	Base voltage defined by ENTSO-E 225 kV	AC-225	225
37	AC-232	AC-232	Base voltage 232 kV	AC-232	232
38	AC-24	AC-24	Base voltage 24 kV	AC-24	24
39	AC-25	AC-25	Base voltage defined by ENTSO-E 25 kV	AC-25	25
40	AC-250	AC-250	Base voltage defined by ENTSO-E 250 kV	AC-250	250
41	AC-26	AC-26	Base voltage defined by ENTSO-E 26 kV	AC-26	26
42	AC-27-5	AC-27-5	Base voltage defined by ENTSO-E 27.5 kV	AC-27-5	27.5
43	AC-275	AC-275	Base voltage defined by ENTSO-E 275 kV	AC-275	275
44	AC-285	AC-285	Base voltage defined by ENTSO-E 285 kV	AC-285	285
45	AC-3-8	AC-3-8	Base voltage defined by ENTSO-E 3.8 kV	AC-3-8	3.8
46	AC-30	AC-30	Base voltage defined by ENTSO-E 30 kV	AC-30	30
47	AC-300	AC-300	Base voltage defined by ENTSO-E 300 kV	AC-300	300
48	AC-31	AC-31	Base voltage defined by ENTSO-E 31 kV	AC-31	31
49	AC-320	AC-320	Base voltage defined by ENTSO-E 320 kV	AC-320	320
50	AC-33	AC-33	Base voltage defined by ENTSO-E 33 kV	AC-33	33
51	AC-330	AC-330	Base voltage defined by ENTSO-E 330 kV	AC-330	330
52	AC-34	AC-34	Base voltage 34 kV	AC-34	34
53	AC-35	AC-35	Base voltage defined by ENTSO-E 35 kV	AC-35	35
54	AC-350	AC-350	Base voltage defined by ENTSO-E 350 kV	AC-350	350
55	AC-36	AC-36	Base voltage defined by ENTSO-E 36 kV	AC-36	36
56	AC-380	AC-380	Base voltage defined by ENTSO-E 380 kV	AC-380	380
57	AC-400	AC-400	Base voltage defined by ENTSO-E 400 kV	AC-400	400
58	AC-450	AC-450	Base voltage defined by ENTSO-E 450 kV	AC-450	450
59	AC-5	AC-5	Base voltage defined by ENTSO-E 5 kV	AC-5	5
60	AC-500	AC-500	Base voltage defined by ENTSO-E 500 kV	AC-500	500
61	AC-6	AC-6	Base voltage defined by ENTSO-E 6 kV	AC-6	6
62	AC-6-3	AC-6-3	Base voltage defined by ENTSO-E 6.3 kV	AC-6-3	6.3
63	AC-600	AC-600	Base voltage defined by ENTSO-E 600 kV	AC-600	600

64	AC-63	AC-63	Base voltage 63 kV	AC-63	63
65	AC-70	AC-70	Base voltage defined by ENTSO-E 70 kV	AC-70	70
66	AC-750	AC-750	Base voltage defined by ENTSO-E 750 kV	AC-750	750
67	AC-9	AC-9	Base voltage 9 kV	AC-9	9

4.2.4 Boundary used

Boundary v1164 was used for model assembly.

The content of the boundary file is shown below:

Class	# of Objects	Description
BaseVoltage	67	Defines a system base voltage which is referenced.
ConnectivityNode	837	Connectivity nodes are points where terminals of AC conducting equipment are connected together with zero impedance.
GeographicalRegion	1	A geographical region of a power system network model.
Junction	837	A point where one or more conducting equipments are connected with zero resistance.
Line	837	Contains equipment beyond a substation belonging to a power transmission line.
SubGeographicalRegion	1	A subset of a geographical region of a power system network model.
Terminal	837	An AC electrical connection point to a piece of conducting equipment. Terminals are connected at physical connection points called connectivity nodes.
TopologicalNode	837	For a detailed substation model, a topological node is a set of connectivity nodes that, in the current network state, are connected together through any type of closed switches, including jumpers. Topological nodes change as the current network state changes (i.e., switches, breakers, etc. change state). For a planning model, switch statuses are not used to form topological nodes. Instead they are manually created or deleted in a model builder tool. Topological nodes maintained this way are also called "busses".
EnergySchedulingType	12	Used to define the type of generation for scheduling purposes.
FullModel	1	Header describing the full model and its contents.

4.3 Data quality checks

4.3.1 Generation Balance checks

The balances are checked against the market data.
 By checking the CGMES file with the following formula
 $Generation = Load + losses + TSO\ balance.$
 The TSO balance is accounted by checking EquivalentInjection net value.

4.3.2 Loading and voltage violations

Continental Europe (CE):

		Undervoltage ($U < 0,9$)	Overvoltage ($U > 1,1$)	Flow limits violations
1	AL	1	1	0
2	AT	0	0	1
3	BA	0	0	6
4	BE	0	0	0
5	BG	0	0	0
6	CH	0	0	0
7	CZ	0	0	1
8	DE	0	0	9
9	DK	0	0	2
10	ES	3	0	4
11	FR	0	34	0
12	GR	7	10	0

13	HR	0	0	0
14	HU	0	0	0
15	IT	0	2	5
16	LU	0	0	0
17	ME	0	0	0
18	MK	4	0	11
19	NL	0	0	14
20	PL	0	0	0
21	PT	13	0	0
22	RO	0	0	0
23	RS	0	1	0
24	SI	0	0	0
25	SK	0	0	0

Baltics:

		Undervoltage ($U < 0,9$)	Overvoltage ($U > 1,1$)	Flow limits violations
1	EE	1	1	0
2	LV	0	0	0
3	LT	0	0	6

4.3.3 Losses

Continental Europe (CE):

		Installed power (MW)	<i>Generated Power (MW)</i>	Load (MW)	Losses
1	AL	2988.74	1429	1348	2.1%
2	AT	28399.7	11169	11469	1%
3	BA	5050.7	3140	1725	2.2%
4	BE	25071.16	12504	11906	1%
5	BG	10986.3	6018	5292	1.9%
6	CH	24370	8877	8696.52	1.5%
7	CZ	19094.6	11532	10246	1%
8	DE	283317	76180	76902	2%
9	DK	13394.14	6492	6070	1.5%
10	ES	130308.6	38429	35173	2.1%
11	FR	166760.5	77825	73435	1.9%
12	GR	31915	6952	6853	2%
13	HR	5637.15	1976	2191	6%
14	HU	11313.5	4529	5530	3.7%
15	IT	128648	38583	46249	1.4%
16	LU	2109	155	1191	5.2%
17	ME	1944	454	535	2.2%

18	MK	2052.1	1189	1174	1.3%
19	NL	42240.83	17363.54	16177	1.9%
20	PL	46073.81	22818	25601	1.4%
21	PT	25294.1	6538	6818	1.5 %
22	RO	20391.66	9928	8282	1.7%
23	RS	10183.47	6506	5870	2.4%
24	SI	4011.89	2484	1818.2	1.1%
25	SK	7734	4054	4642	0.70%
TOTAL			377124.5	375193.7	2%

Baltics:

		Installed power (MW)	<i>Generated Power (MW)</i>	Load (MW)	Losses
1	EE	2766	496.59	1290	1.90%
2	LV	29581.01	9187.15	9181.2	0.70%
3	LT	4937	1925.7	1769.6	1.80%

5. Merged model analysis

5.1 Model content

Network models for TYNDP 2020 will be provided in the ENTSO-E CIM CGMES data exchange format. The overall model content based on CGMES 2.4.15 classes is shown below.

Class	AL	AT	BA	BE	CH	CZ	DE	DK	ES	FR	GR	HR	HU	IT	LU	ME	MK	NL	PL	PT	RO	RS	SI	SK	Total	
ACLLineSegment	202	784	326	755	311	118	1591	314	1231	2225	1808	366	792	1038	45	112	155	1228	393	606	186	798	283	53	15720	
BaseVoltage	2		3	8			16		15	5	5		1	24	2	2	10	14	1						5	113
Breaker		214		7			518			806				1	9			5								1346
BusbarSection	269	723	299	917	159	76	2351	251	1271	2815	2188	226	825		50	248	144	1199	369	605	128	1373		34	15245	
ConformLoad	93	185	143	278	166	40		151	2241	1049	354	331	280		28		100		175	91	88	336			5598	
ConformLoadGroup	93	1	1	1	15	1		1	1	1049	354	331	280		1		1		175	91	88	1			2483	
ConnectivityNode	282				181						2189	226	825						369	605				34	4711	
ControlArea	1	1			1		2		1	1	1	1	1			1	1		1	1	1	1		1	17	
ControlAreaGeneratingUnit	1				1				1	1	1	2	1			1	1			1	4	1		2	18	
CurrentLimit	1476	3214	2154	1787	2869	256	3703	794	7789	12792	16332	810	6492	6729	118	552	617	4082	9006	4658	444	6558	1872	321	95425	
Disconnecter		1		6	2		3	1										1							13	
EnergyConsumer							1439							1157				327					157	21	3101	
EquivalentBranch				18			91	22	4							2			216						353	
EquivalentInjection	7	61	27	21	41	18	100	26	19	48	8	15	20	36	15	13	8	15	17	10	10	19	18	12	584	
EquivalentNetwork									4							2									6	
EquivalentShunt																			171						171	
ExternalNetworkInjection						35	182																		217	
GeneratingUnit	2	295		423	169	98	2263	163	1693	1903	308	20	424	1688	7	1	2	473	623	112	34	2	18	48	10769	
GeographicalRegion	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	24
HydroGeneratingUnit	106	391	43	45	193	29	609		928	649	55	39	14	893	12	24	22	5	162	116	52	52	63	23	4525	
HydroPowerPlant		391		45	207	29	609		928	579	55	39	14		12					116	52			23	3099	
Line				672		118		314		48					45			116	376				283		1972	
LinearShuntCompensator	5	54		42		8	110	85	184	393	Xxx	6	40	101			6	168	51	68	15			24	1360	
LoadArea	1	1	1	1	1				1		1	1	1			1	1		1	1	1	1		1	14	
LoadBreakSwitch							14																		14	
LoadResponseCharacteristic	93	202	144		80		1439		2405	2005	354	331	390	1157	1	80	100		1	91	88	405		21	9387	

Class	AL	AT	BA	BE	CH	CZ	DE	DK	ES	FR	GR	HR	HU	IT	LU	ME	MK	NL	PL	PT	RO	RS	SI	SK	Total		
MutualCoupling																		164							164		
NonConformLoad		17	1		3				164	956			110			20									69	1083	
NonConformLoadGroup		1	1		3				1	956			110			1										1	833
NonlinearShuntCompensator								38																		38	
NonlinearShuntCompensatorPoint								825																		825	
NuclearGeneratingUnit					2	10			7	57			8					1			2			1	6	94	
OperationalLimitSet	943	2018	1057	2019	3462	332	3703	1045	4494	5463	7632	1036	2989	4651	119	750		4082	3524	2487	572	4649	624	145	57796		
OperationalLimitType	7	2	7	3	7	3	1	3	7	6	7	7	6	2575	3	7	7	1	3	7	7	7	3	7	7	2693	
PhaseTapChangerAsymmetrical		115			1		1	1										4	1					2		124	
PhaseTapChangerLinear				21		4													13	4						42	
PhaseTapChangerSymmetrical		8			17		10		4					15												54	
PhaseTapChangerTable								7		14					1			3								25	
PhaseTapChangerTablePoint								155		464					33			99								751	
PhaseTapChangerTabular								7		14					1			3								25	
PowerTransformer	116	181	106	114	48	8	193	78	440	649	875	39	290	1285	14	110	45	653	246	335	36	820	29	1	6711		
PowerTransformerEnd	270	450	212	275	96	20	513	166	1033	1298	1826	78	580	2573	28	299	108	1514	506	670	72	1958	58	3	14606		
RatioTapChanger	145	58		65	29	4	55	44	149	289	256	69	95	554	11	80	10	406	231	364	36	199	24	1	3174		
RatioTapChangerTable								36		232																36	
RatioTapChangerTablePoint								754		1606																754	
RegulatingControl	77	833	73	100	114	210	396	109	3424	3508	816	52	310	4104	13	31	42	47	217	217	94	105	8	23	14923		
SeriesCompensator							4											56								60	
StaticVarCompensator								1		7																8	

SubGeographicalRegion	2	1	4	1065	1	1	6	3	5	7	2	1	1	20	4	2	1	18	1	14	1	1	1	1	1163
SubLoadArea	1		1		1				1		1	1	1			1	1		1	1	1	1			13
Substation	269	300	204	393	130	49	691	175	707	1313	2190	226	411	698	38	58	95	615	144	471	94	428	149	27	9875
Class	AL	AT	BA	BE	CH	CZ	DE	DK	ES	FR	GR	HR	HU	IT	LU	ME	MK	NL	PL	PT	RO	RS	SI	SK	Total
Switch									47							36	4						114		201
SynchronousMachine	114	927	73	689	373	210	4668	271	3240	3501	660	93	497	4104	23	31	36	732	1017	297	156	105	97	109	22023
TapChangerControl	19	181		47	20	4		42	153	54	138	26	54	569	1		10	69	202	150	25	199	26	1	1990
Terminal	1162	4415	1407	3800	1464	648	14727	1663	10716	16129	8826	1481	3936	10049	252	971	720	6534	3524	2953	841	5684	901	311	103114
ThermalGeneratingUnit	3	41	13	86		55	352	16	87	149	47	10	31	1152		2	10	198	81	16	51	23	7	11	2441
TieFlow		61	34				100			48										17					260
VoltageLevel	269	457	275	578	159	63	1333	244	1035	1685	2191	226	545	1904	18	145	125	967	293	574	115	1029	169	29	14428
VoltageLimit	1076		1196		2480				5084		8752	904	3300			992	576			2420	512	5592		136	33020
WindGeneratingUnit	3	91	12	135	9	18	668	91	525	743	250	24	20	371	4	3	2	159	151	53	17	27	1	5	3382
Total	7110,00	16256	7818	14137	12816	2350	42462	7897	50040	63199	58483	7018	23695	47449,00	881	4579	2961	22760	22279	18206	3824	30564	4795	1435	473014

Total

Class	EE	LT	LV	Total
ACLineSegment	339	592	338	15111
BaseVoltage	4			184
Breaker		112		2066
BusbarSection	385	560	299	17022
ConformLoad	168	392	148	5126
ConformLoadGroup	168	392	148	2127
ConnectivityNode	385	560	299	3041
ControlArea	1	1	1	154
ControlAreaGeneratingUnit	1	1	1	16
CurrentLimit	2204	4458	1230	80466
Disconnecter				781
EnergyConsumer		44		3684
EquivalentBranch				2266
EquivalentInjection	8	26	12	519
EquivalentNetwork				4

EquivalentShunt				175
ExternalNetworkInjection				3924
GeneratingUnit	15	13	2	8286
GeographicalRegion	1	1	1	24
HydroGeneratingUnit		9	24	3775
HydroPowerPlant		9	24	1722
Line				2165
LinearShuntCompensator	37	15	6	1799
LoadArea	1	1	1	14
LoadBreakSwitch				14
LoadResponseCharacteristic	191	458	154	8538


Class	EE	LT	LV	Total
MutualCoupling				164
NonConformLoad	23	66	6	959
NonConformLoadGroup	23	66	6	717
NonlinearShuntCompensator				36
NonlinearShuntCompensatorPoint				846
NuclearGeneratingUnit				85
OperationalLimitSet	1163	2120	977	
OperationalLimitType	7	7	7	2473
PhaseTapChangerAsymmetrical				46
PhaseTapChangerLinear				24
PhaseTapChangerSymmetrical				46

PhaseTapChangerTable				23
PhaseTapChangerTablePoint				691
PhaseTapChangerTabular				23
PowerTransformer	53	77	68	6621
PowerTransformerEnd	132	154	136	15310
RatioTapChanger		78	67	4030
RatioTapChangerTable				30
RatioTapChangerTablePoint				634
RegulatingControl	35	45	44	13033
SeriesCompensator				35
StaticVarCompensator				8
SubGeographicalRegion	19	8	8	115
SubLoadArea	1		1	12
Substation	264	448	299	8500
Switch				371
SynchronousMachine	36	41	40	15921
TapChangerControl	9	14		3160
Terminal	1777	2662	1323	105771
ThermalGeneratingUnit	8		7	1105
TieFlow				3434
VoltageLevel	264	448	299	15452
VoltageLimit	1540		1196	25518
WindGeneratingUnit	13	19	7	2657
Total	9229,00	12307,00	6781,00	28317,00

5.1.1 AC Lines

There are 18881 lines in the NT2025_CE model. Of these, 270 AC tie- lines between TSOs connections. When the model is merged both sides of the line segment are connected to the boundary point. The equivalent injections on the IGM are disconnected. The flows on the tie line will be as per the load flow results.

The AC tie line represented in CGMES is shown below.



- XPE_PI21
- XWE_LE11
- XOB_MB11
- XRE_PA11
- XLA_GU22
- XGR_IM51
- XTR_PL21
- XBU_KO51
- XZE_KA11
- XSA_RI11
- XAV_AV12
- XNE_BR51
- XRI_CO21
- XGR_HG12
- XBA_KF31
- XFL_KA11
- XOT_LA11
- XZV_BI51
- XVY_MB12
- XAU_M.21
- XRO_SF11

XTR_BL21
 XDI_ME13
 XDU_SL11
 XBR_AV11
 XTU_DA11
 XZE_HE12
 XVI_KR11
 XCM_ST11
 XYV_SI22
 XSI_MB11
 XDT_DB11
 XLA_GU21
 XVE_GE22
 XFO_PL11
 XTR_KO51
 XB_CA21
 XS_CO21
 XME_CA11
 XLA_KU12
 XBB_LI51
 XGY_GA11
 XAA_BO12
 XNA_PR12
 XNE_OP51
 XPL_ZA51
 XED_KL11
 XME_DI11
 XER_PE12
 XCA_AL12
 XST_VR11
 XVD_PO21
 XOR_ZU51
 XPR_SI21
 XVL_VE12
 XKO_TI12
 XGO_ME21
 XVE_GE21
 XKA_MA12
 XAL_LG11
 XZE_CI11
 XGR_DA11
 XST_PR52
 XTR_LA11
 XTU_DA21
 XRE_PA12
 XLI_KO21
 XJA_KA12
 XMA_IB51
 XMO_KO11
 XAR_AR21
 XBI_SO21
 XLA_KU21

XVK_BR51
 XJO_JO21
 XED_KL12
 XBA_MA11
 XEN_SA21
 XKA_KO11
 XHE_CI12
 XTR_PE21
 XPA_DI21
 XWE_WB22
 XWE_WB21
 XTU_KR11
 XLI_BU21
 XWE_LE13
 XSK_KP51
 XJO_JO22
 XHR_RO12
 XYV_SI21
 XLA_EN11
 XJO_JO24
 XWU_SO21
 XFI_PR21
 XBG_TH11
 XBA_KF32
 XNO_VA12
 XLI_AU21
 XUG_SM11
 XMN_BR21
 XWE_SI2B
 XVA_MG11
 XVI_KR12
 XAU_MO22
 XBE_TI13
 XZU_SZ11
 XNZ_SO22
 XKR_LE12
 XVY_MB11
 XWE_KE21
 XAL_PN21
 XHR_ET11
 XSR_LJ51
 XEL_BI11
 XWE_PR12
 XMN_RU21
 XCA_ME21
 XLA_KU13
 XAL_RO11
 XAC_LO12
 XPL_BI21
 XBA_SI11
 XZU_GY11
 XRO_B.11

XWA_BR21
 XER_SM11
 XBI_SO22
 XUG_ER11
 XOB_PO21
 XEN_VI11
 XAA_BO11
 XBI_NI51
 XKR_ZA13
 XCA_AL11
 XDI_ME14
 XJO_JO25
 XNS_VI22
 XKA_PG11
 XSO_NI11
 XSA_PI21
 XKR_ZA14
 XWI_GY21
 XPR_ME21
 XDO_MG11
 XSA_AR11
 XWE_LE12
 XWE_BR12
 XNE_ST51
 XSJ_BR51
 XAL_RO12
 XQU_HE21
 XPI_GI12
 XCE_FR11
 XBA_VI22
 XEI_VO21
 XKU_ZA51
 XKR_LE11
 XOB_RA21
 XNA_PR11
 XMA_MU11
 XEI_MU12
 XVI_VA21
 XJO_JO23
 XKO_LA11
 XKA_KB11
 XWE_BR21
 XAL_PO21
 XAV_MA12
 XAC_LO11
 XOB_RA11
 XHE_AR11
 XEM_EE11
 XMI_NS11
 XLI_PO22
 XNA_GL21
 XKO_LA12

XNS_VI21
 XBI_PR21
 XBI_LE51
 XRO_GO11
 XTH_DU11
 XNE_GY21
 XNR_DT11
 XRI_AV21
 XBA_VI21
 XRI_VA21
 XPL_BB21
 XBR_VR51
 XPE_AH21
 XGR_TA41
 XAS_SI11
 XFL_KA12
 XER_PE11
 XVA_PR21
 XPE_PT11
 XBE_NA11
 XPF_DJ11
 XFL_BI11
 XLA_TI11
 XHG_MI12
 XJA_KA11
 XAL_PN22
 XKV_GR51
 XPE_SI21
 XLA_KU22
 XBA_FL21
 XNZ_SO21
 XVE_B.11
 XPE_IS12
 XSO_SE11
 XGN_GA11
 XVI_BA11
 XCA_OP51
 XSA_PN21
 XPE_SU51
 XEI_MU13
 XAU_SA21
 XBI_MO31
 XKR_ZA12
 XMO_BE21
 XWE_SI2A
 XEI_MU11
 XTU_KR12
 XBE_TI11
 XSK_UR11
 XHR_RO11
 XMO_CH21
 XSO_ST11


XBE_TI21
 XGR_HG11
 XDU_SL12
 XPE_DI21
 XSE_PA21
 XTR_PL22
 XPE_PT21
 XEN_VI14
 XRE_DI11
 XAU_BE21
 XWE_SI2C
 XEN_VI13
 XSO_ME11
 XKR_ZA11
 XSA_SU11
 XNE_FO51
 XPU_TV11
 XGN_VD11
 XKA_MA11
 XKO_TI11
 XNR_DT12
 XLA_SI11
 XPE_IS11
 XPE_PT12
 XMN_RU22
 XPI_GI11
 XTR_HN51
 XRI_PE11
 XST_PR51
 XNO_WI11
 XAS_KU11
 XGR_DA21
 XZE_CI21
 XWE_PR11
 XGO_LE11
 XPR_ET11
 XEN_VI12
 XHG_MI11
 XLA_KU11
 XRA_BR51
 XBA_RO21


5.1.2 PST

PST in the NT2025_CE model correspond to transformers with the following associated CGMES classes:

PhaseTapChangerAsymmetrical
 PhaseTapChangerLinear
 PhaseTapChangerSymmetrical
 PhaseTapChangerTabular

5.2 HVDC and external network connections location





The following elements are single connection X-nodes:

XGU_SI51
 XPL_BI11
 XGA_CU1E
 XMO_ZA21
 XRO_MU11
 XTR_HE21
 XPF_DJ12
 XDI_CA1E
 XBI_R21_K
 XBI_R11_K
 XBE_GB2B
 XVG_BB11
 XDI_ME12
 XTI_MU21
 XWB_BR21
 XJO_OR11
 XBA_ZA01
 XAV_DW1P
 XNS_BA11
 XMI_HA11
 XBE_DE42
 XMO_TU12
 XAV_DW1K
 XJI_KI51
 XEL_AL12
 XMI_HA12
 XSI_VE11
 XWB_BR11

XBR_SL51
 XHW_KR1D
 XTA_FA11
 XTJ_K41K
 XDI_CA1F
 XDI_ME11
 XVR_RE41
 XBW_BJ1K
 XED_EE1N
 XMO_TE31
 XSA_HO11
 XWI_TO1D
 XMA_SE11
 XTJ_K31K
 XSA_BE1S
 XSA_MA1F
 XGR_MA1N
 XPL_PO11
 XED_EE1D
 XLL_BA1E
 XBW_BJ1D
 XTJ_K13K
 XSA_LU21
 XLI_OB1A
 XAV_AV11
 XGA_CU1F
 XFG_HK12
 XTJ_K23K
 XVH_L11K
 XAR_GA1G
 XVH_L21K
 XEH_GB11
 XBW_BJ2K
 XBW_BJ2D
 XEH_GB12
 XVI_KR21
 XNL_GB2
 XAR_GA1I
 XFG_HK11
 XIE_FR42
 XAU_BA21
 XVK_MU11
 XTA_FA12
 XKI_MU21
 XSA_MA1E
 XDR_ZR1P
 XTO_CH11
 XMA_SE13
 XBA_MU11
 XME_EX11
 XAU_BA22
 XNI_SI51

XGU_HU1D
 XVI_KR22
 XMA_SE15
 XLI_OB1B
 XOM_DJ51
 XER_SO11
 XGU_HU2D
 XPA_EL9I
 XLL_BA1F
 XEL_AL11
 XZE_HE11
 XSA_GO11
 XMO_TE32
 XAV_MA11
 XEE_FE1N
 XBM_AP51
 XBE_SA1S
 XSL_SW11
 XDE_ZA41
 XBG_KN51
 XSO_NI12
 XFE_GR1D
 XVI_PO11
 XBE_GB1B
 XSI_VE1S

 XVR_LJ51
 XSK_KB12
 XSV_BA11
 XVI_ZA51
 XMO_ZA21
 XAH_NA
 XVK_IS11
 XVG_BI11
 XDA_TO
 XBL_LI11

Number of single connected elements after merging is 115.

6. Merged model specification

NT2025_CE model is composed of 25 IGMs and one BD file. Once the assembly is done the model has been tested for convergence and the balances and losses checked.

NT2025 Baltics model is composed of 3 IGMs and one BD file.

6.1 Load flow study

6.1.1 CE Synchronous area

It is possible with the assembled model to run a load flow study with reactive limits enabled.

On this model 3 slacks are used for the CE model.

FLAMAP7	(FR)
F.20L1	(IT)
AVV_0201	(DK)

If balancing on the slack is selected for the solution, it is recommended to increase the reactive power capability on the FLAMAP7 slack to -600, 600 MVAR.

It is recommended to set the HVDC exchanges to the same values in both sides of the interconnections. The model converges in 11 iterations with the selected slacks and the recommended settings.

In case of inserting a model of the HVDC link, the balances of the EquivalentInjections indicated on both sides of the link should be maintained to keep the balances.

The results for load flow are shown below:

Project:			
2020	Date:	12/2020	
Load Flow Calculation		Grid Summary	
AC Load Flow, balanced, positive sequence	Automatic Model Adaptation for Convergence		
No			
Automatic tap adjustment of transformers	No	Max. Acceptable Load Flow Error	
Consider reactive power limits	Yes	Bus Equations(HV)	1,00 kVA
	Model Equations	0,10 %	
Grid: AL	System Stage: AL	Study Case: Study Case	Annex: / 1
Grid: AL	Summary		
No. of Substations	269	No. of Busbars	269
No. of Terminals	0	No. of Lines	
No. of 2-w Trfs.	78	No. of 3-w Trfs.	38
No. of syn. Machines	114	No. of	
asyn.Machines	0	No. of Shunts/Filters	5
No. of Loads	93	No. of SVS	0
Generation	= 1429,36 MW	98,33 Mvar	1432,74 MVA
External Infeed	= 0,00 MW	0,00 Mvar	0,00 MVA
Inter Grid Flow	= 56,20 MW	-23,81 Mvar	
Load P(U)	= 1348,21 MW	473,49 Mvar	1428,94 MVA
Load P(Un)	= 1348,21 MW	473,49 Mvar	1428,94 MVA
Load P(Un-U)	= -0,00 MW	0,00 Mvar	
Motor Load	= 0,00 MW	0,00 Mvar	0,00 MVA
Grid Losses	= 24,95 MW	-351,35 Mvar	
Line Charging	=	-648,31 Mvar	
Compensation ind.	=	0,00 Mvar	
Compensation cap.	=	0,00 Mvar	
Installed Capacity	= 2651,52 MW		
Spinning Reserve	= 883,42 MW		

Total Power Factor:			
Generation	=	1,00 [-]	

--			
Grid: AL	System Stage: AL	Study Case: Study Case	Annex: / 2

--			
Load/Motor	=	0,94 / 0,00 [-]	

--			
Inter Grid Flow to			
GR	=	-49,24 MW	6,41 Mvar
MK	=	-94,02 MW	-20,15 Mvar
ME	=	62,62 MW	-20,02 Mvar
RS	=	136,84 MW	9,96 Mvar
Total	=	56,20 MW	-23,81 Mvar

--
 | Grid: AT System Stage: AT | Study Case: Study Case | Annex: / 3
 |

--
 | Grid: AT Summary
 |
 | No. of Substations 457 No. of Busbars 723 No. of Terminals 0 No. of Lines
 784 |
 | No. of 2-w Trfs. 93 No. of 3-w Trfs. 88 No. of syn. Machines 927 No. of
 asyn.Machines 0 |
 | No. of Loads 202 No. of Shunts/Filters 54 No. of SVS 0 |
 |
 | Generation = 11167,90 MW -347,30 Mvar 11173,30 MVA |
 | External Infeed = 0,00 MW 0,00 Mvar 0,00 MVA |
 | Inter Grid Flow = -421,05 MW -115,14 Mvar |
 | Load P(U) = 11467,66 MW 982,15 Mvar 11509,64 MVA |
 | Load P(Un) = 11467,66 MW 982,15 Mvar 11509,64 MVA |
 | Load P(Un-U) = 0,00 MW -0,00 Mvar |
 | Motor Load = 0,06 MW 166,72 Mvar 166,72 MVA |
 | Grid Losses = 121,22 MW -2763,61 Mvar |
 | Line Charging = -3915,36 Mvar |
 | Compensation ind. = 1494,58 Mvar |
 | Compensation cap. = -112,00 Mvar |
 |
 | Installed Capacity = 43068,88 MW |
 | Spinning Reserve = 17231,81 MW |
 |
 | Total Power Factor:
 | Generation = 1,00 [-] |
 |

--
 | Grid: AT System Stage: AT | Study Case: Study Case | Annex: / 4
 |

--
 | Load/Motor = 1,00 / 0,00 [-] |
 |

--
 | Inter Grid Flow to
 | DE = -1455,45 MW -478,17 Mvar |
 | IT = 863,16 MW -100,88 Mvar |
 | CZ = -520,66 MW 173,68 Mvar |
 | HU = -80,10 MW -30,05 Mvar |
 | CH = 865,91 MW 108,30 Mvar |
 | SI = -93,91 MW 211,97 Mvar |

Total	=	-421,05 MW	-115,14 Mvar	

--
 | Grid: BA System Stage: BA | Study Case: Study Case | Annex: / 5
 |

--
 | Grid: BA Summary | |
 | No. of Substations 275 No. of Busbars 299 No. of Terminals 0 No. of Lines
 324 |
 | No. of 2-w Trfs. 106 No. of 3-w Trfs. 0 No. of syn. Machines 73 No. of
 asyn.Machines 0 |
 | No. of Loads 144 No. of Shunts/Filters 0 No. of SVS 0 |
 |
 | Generation = 3139,71 MW -32,33 Mvar 3139,88 MVA |
 | External Infeed = 0,00 MW 0,00 Mvar 0,00 MVA |
 | Inter Grid Flow = 1356,31 MW -335,78 Mvar |
 | Load P(U) = 1724,51 MW 565,23 Mvar 1814,78 MVA |
 |
 | Load P(Un) = 1724,51 MW 565,23 Mvar 1814,78 MVA |
 |
 | Load P(Un-U) = -0,00 MW 0,00 Mvar |
 | Motor Load = 0,00 MW 0,00 Mvar 0,00 MVA |
 | Grid Losses = 58,89 MW -261,78 Mvar |
 | Line Charging = -923,48 Mvar |
 | Compensation ind. = 0,00 Mvar |
 | Compensation cap. = 0,00 Mvar |
 |
 | Installed Capacity = 2312,15 MW |
 | Spinning Reserve = 525,34 MW |
 |
 | Total Power Factor:
 | Generation = 1,00 [-] |
 |

--
 | Grid: BA System Stage: BA | Study Case: Study Case | Annex: / 6
 |

--
 | Load/Motor = 0,95 / 0,00 [-] |
 |

--
 | Inter Grid Flow to | |
 | HR = 1253,15 MW -201,47 Mvar |
 | RS = 176,39 MW -112,77 Mvar |
 | ME = -73,22 MW -21,54 Mvar |
 | Total = 1356,31 MW -335,78 Mvar |
 |

--						
Grid: BE	System Stage: BE		Study Case: Study Case		Annex:	/ 7
--						
Grid: BE	Summary					
No. of Substations	578	No. of Busbars	729	No. of Terminals	94	No. of Lines
755						
No. of 2-w Trfs.	67	No. of 3-w Trfs.	47	No. of syn. Machines	689	No. of
asyn.Machines	0					
No. of Loads	278	No. of Shunts/Filters	42	No. of SVS	0	
Generation	=	12504,37 MW	-2122,27 Mvar	12683,19 MVA		
External Infeed	=	0,00 MW	0,00 Mvar	0,00 MVA		
Inter Grid Flow	=	484,91 MW	699,79 Mvar			
Load P(U)	=	11906,09 MW	1296,63 Mvar	11976,49 MVA		
Load P(Un)	=	11906,09 MW	1296,63 Mvar	11976,49 MVA		
Load P(Un-U)	=	0,00 MW	-0,00 Mvar			
Motor Load	=	0,00 MW	0,00 Mvar	0,00 MVA		
Grid Losses	=	113,36 MW	-3926,05 Mvar			
Line Charging	=		-5614,73 Mvar			
Compensation ind.	=		1909,36 Mvar			
Compensation cap.	=		-2101,99 Mvar			
Installed Capacity	=	25295,00 MW				
Spinning Reserve	=	12566,79 MW				
Total Power Factor:						
Generation	=	0,99 [-]				

--						
Grid: BE	System Stage: BE		Study Case: Study Case		Annex:	/ 8
--						
Load/Motor	=	0,99 / 0,00 [-]				
--						
Inter Grid Flow to						
FR	=	2045,97 MW	-160,34 Mvar			
NL	=	-1401,05 MW	737,95 Mvar			
LU	=	-262,01 MW	58,90 Mvar			
EU	=	102,00 MW	63,28 Mvar			
Total	=	484,91 MW	699,79 Mvar			

--
 | Grid: BG System Stage: BG | Study Case: Study Case | Annex: / 9
 |

--
 | Grid: BG Summary | |
 | No. of Substations 692 No. of Busbars 797 No. of Terminals 0 No. of Lines
 862 |
 | No. of 2-w Trfs. 248 No. of 3-w Trfs. 0 No. of syn. Machines 185 No. of
 asyn.Machines 0 |
 | No. of Loads 625 No. of Shunts/Filters 33 No. of SVS 0 |
 |
 | Generation = 6018,09 MW 547,55 Mvar 6042,95 MVA |
 | External Infeed = 0,00 MW 0,00 Mvar 0,00 MVA |
 | Inter Grid Flow = 600,55 MW 76,67 Mvar |
 | Load P(U) = 5292,22 MW 1583,62 Mvar 5524,08 MVA |
 |
 | Load P(Un) = 5292,22 MW 1583,62 Mvar 5524,08 MVA |
 |
 | Load P(Un-U) = 0,00 MW 0,00 Mvar |
 | Motor Load = 0,00 MW 0,00 Mvar 0,00 MVA |
 | Grid Losses = 125,32 MW -1112,74 Mvar |
 | Line Charging = -2792,60 Mvar |
 | Compensation ind. = 0,00 Mvar |
 | Compensation cap. = 0,00 Mvar |
 |
 | Installed Capacity = 9830,03 MW |
 | Spinning Reserve = 2362,61 MW |
 |
 | Total Power Factor:
 | Generation = 1,00 [-] |
 |

--
 | Grid: BG System Stage: BG | Study Case: Study Case | Annex: / 10
 |

--
 | Load/Motor = 0,96 / 0,00 [-] |
 |

--
 | Inter Grid Flow to | |
 | MK = 6,25 MW 24,76 Mvar |
 | RS = 201,37 MW -18,60 Mvar |
 | EU = 900,00 MW -0,00 Mvar |
 | GR = 243,06 MW -41,17 Mvar |
 | RO = -750,13 MW 111,68 Mvar |
 | Total = 600,55 MW 76,67 Mvar |



 --
 | Grid: CH System Stage: CH | Study Case: Study Case | Annex: / 11
 |

 --
 | Grid: CH Summary | |
 | No. of Substations 159 No. of Busbars 159 No. of Terminals 22 No. of Lines
 311 |
 | No. of 2-w Trfs. 48 No. of 3-w Trfs. 0 No. of syn. Machines 373 No. of
 asyn.Machines 0 |
 | No. of Loads 169 No. of Shunts/Filters 0 No. of SVS 0 |
 |
 | Generation = 8877,39 MW -696,21 Mvar 8904,65 MVA |
 | External Infeed = 0,00 MW 0,00 Mvar 0,00 MVA |
 | Inter Grid Flow = 56,11 MW -1241,10 Mvar |
 | Load P(U) = 8696,48 MW 1771,25 Mvar 8875,02 MVA |
 |
 | Load P(Un) = 8696,48 MW 1771,25 Mvar 8875,02 MVA |
 |
 | Load P(Un-U) = 0,00 MW 0,00 Mvar |
 | Motor Load = 0,00 MW 0,00 Mvar 0,00 MVA |
 | Grid Losses = 124,80 MW -1226,35 Mvar |
 | Line Charging = -2631,98 Mvar |
 | Compensation ind. = 0,00 Mvar |
 | Compensation cap. = 0,00 Mvar |
 |
 | Installed Capacity = 19471,50 MW |
 | Spinning Reserve = 7579,61 MW |
 |
 | Total Power Factor:
 | Generation = 1,00 [-] |

 --
 | Grid: CH System Stage: CH | Study Case: Study Case | Annex: / 12
 |

 --
 | Load/Motor = 0,98 / 0,00 [-] |

 --
 | Inter Grid Flow to | |
 | IT = 4484,76 MW -445,20 Mvar |
 | DE = -1589,62 MW -846,67 Mvar |
 | EU = 50,00 MW -0,02 Mvar |
 | FR = -2023,11 MW 159,08 Mvar |
 | AT = -865,91 MW -108,30 Mvar |
 | Total = 56,11 MW -1241,10 Mvar |



--
 | Grid: CZ System Stage: CZ | Study Case: Study Case | Annex: / 13
 |

--
 | Grid: CZ Summary
 |
 | No. of Substations 63 No. of Busbars 76 No. of Terminals 0 No. of Lines
 118 |
 | No. of 2-w Trfs. 4 No. of 3-w Trfs. 4 No. of syn. Machines 210 No. of
 asyn.Machines 0 |
 | No. of Loads 40 No. of Shunts/Filters 13 No. of SVS 0 |
 |
 | Generation = 11532,10 MW -21,41 Mvar 11532,12 MVA
 |
 | External Infeed = 0,00 MW 0,00 Mvar 0,00 MVA
 | Inter Grid Flow = 1189,48 MW -837,66 Mvar
 | Load P(U) = 10246,07 MW 1602,00 Mvar 10370,55 MVA
 |
 | Load P(Un) = 10246,07 MW 1602,00 Mvar 10370,55 MVA
 |
 | Load P(Un-U) = 0,00 MW 0,00 Mvar
 | Motor Load = 0,00 MW 0,00 Mvar 0,00 MVA
 | Grid Losses = 96,56 MW -1905,29 Mvar
 | Line Charging = -2928,76 Mvar
 | Compensation ind. = 1119,55 Mvar
 | Compensation cap. = 0,00 Mvar
 |
 | Installed Capacity = 22230,28 MW
 | Spinning Reserve = 7562,50 MW
 |
 | Total Power Factor:
 | Generation = 1,00 [-]
 |

--
 | Grid: CZ System Stage: CZ | Study Case: Study Case | Annex: / 14
 |

--
 | Load/Motor = 0,99 / 0,00 [-]
 |

--
 | Inter Grid Flow to
 | AT = 520,66 MW -173,68 Mvar
 | PL = 59,04 MW -193,25 Mvar
 | SK = 523,43 MW -167,90 Mvar
 | DE = 86,34 MW -302,84 Mvar
 | Total = 1189,48 MW -837,66 Mvar
 |



--
 | Grid: DE System Stage: DE | Study Case: Study Case | Annex: / 15
 |

--
 | Grid: DE Summary | |
 | No. of Substations 1333 No. of Busbars 2351 No. of Terminals 91 No. of Lines
 1591 |
 | No. of 2-w Trfs. 66 No. of 3-w Trfs. 127 No. of syn. Machines 4667 No. of
 asyn.Machines 0 |
 | No. of Loads 1439 No. of Shunts/Filters 110 No. of SVS 4 |
 |
 | Generation = 76179,67 MW -2361,12 Mvar 76216,25 MVA |
 | External Infeed = 0,00 MW -1860,18 Mvar 1860,18 MVA |
 | Inter Grid Flow = -2390,45 MW 2569,00 Mvar |
 | Load P(U) = 76901,53 MW 26,10 Mvar 76901,53 MVA |
 | Load P(Un) = 76901,53 MW 26,10 Mvar 76901,53 MVA |
 |
 | Load P(Un-U) = 0,00 MW 0,00 Mvar |
 | Motor Load = 0,00 MW 0,00 Mvar 0,00 MVA |
 | Grid Losses = 1668,59 MW -10117,79 Mvar |
 | Line Charging = -27896,54 Mvar |
 | Compensation ind. = 3954,71 Mvar |
 | Compensation cap. = -653,31 Mvar |
 |
 | Installed Capacity = 294076,23 MW |
 | Spinning Reserve = 207123,95 MW |
 |
 | Total Power Factor:
 | Generation = 1,00 [-] |

--
 | Grid: DE System Stage: DE | Study Case: Study Case | Annex: / 16
 |

--
 | Load/Motor = 1,00 / 0,00 [-] |

--
 | Inter Grid Flow to |
 | AT = 1455,45 MW 478,17 Mvar |
 | CH = 1589,62 MW 846,67 Mvar |
 | NL = -207,54 MW 427,36 Mvar |
 | FR = -1755,70 MW 324,33 Mvar |
 | CZ = -86,34 MW 302,84 Mvar |

LU	=	1137,68 MW	204,61 Mvar	
EU	=	-3517,00 MW	-67,41 Mvar	
DK	=	-2947,28 MW	-58,46 Mvar	
PL	=	1940,66 MW	110,89 Mvar	
Total	=	-2390,45 MW	2569,00 Mvar	

--
 | Grid: DK System Stage: DK | Study Case: Study Case | Annex: /
 17 |

--

Grid: DK	Summary					
No. of Substations	244	No. of Busbars	251	No. of Terminals	7	No. of Lines
No. of 2-w Trfs.	68	No. of 3-w Trfs.	10	No. of syn. Machines	271	No. of
asyn.Machines	0	No. of Shunts/Filters	123	No. of SVS	1	
No. of Loads	151					
Generation	= 6490,12 MW	-773,51 Mvar		6536,05 MVA		
External Infeed	= 0,00 MW	0,00 Mvar		0,00 MVA		
Inter Grid Flow	= 320,30 MW	58,46 Mvar				
Load P(U)	= 6070,00 MW	1875,20 Mvar		6353,05 MVA		
Load P(Un)	= 6070,00 MW	1875,20 Mvar		6353,05 MVA		
Load P(Un-U)	= -0,00 MW	-0,00 Mvar				
Motor Load	= 0,00 MW	0,00 Mvar		0,00 MVA		
Grid Losses	= 99,82 MW	-5818,36 Mvar				
Line Charging	=	-6958,19 Mvar				
Compensation ind.	=	3615,84 Mvar				
Compensation cap.	=	-504,66 Mvar				
Installed Capacity	= 14448,75 MW					
Spinning Reserve	= 6904,02 MW					
Total Power Factor:						
Generation	= 0,99 [-]					

--
 | Grid: DK System Stage: DK | Study Case: Study Case | Annex: /
 18 |

--
 | Load/Motor = 0,96 / 0,00 [-]

--

Inter Grid Flow to					
EU	= -2626,98 MW	-0,00 Mvar			
DE	= 2947,28 MW	58,46 Mvar			
Total	= 320,30 MW	58,46 Mvar			

 --
 | Grid: ES System Stage: ES | Study Case: Study Case | Annex: / 19 |

--
 | Grid: ES Summary | |
 | No. of Substations 1035 No. of Busbars 1271 No. of Terminals 0 No. of Lines
 1231 |
 | No. of 2-w Trfs. 287 No. of 3-w Trfs. 153 No. of syn. Machines 3240 No. of
 asyn.Machines 0 |
 | No. of Loads 2405 No. of Shunts/Filters 184 No. of SVS 0 |
 |
 | Generation = 38429,25 MW -156,36 Mvar 38429,56 MVA |
 | External Infeed = 0,00 MW 0,00 Mvar 0,00 MVA |
 | Inter Grid Flow = 2516,41 MW 185,43 Mvar |
 | Load P(U) = 35173,08 MW 1110,89 Mvar 35190,61 MVA |
 |
 | Load P(Un) = 35173,08 MW 1110,89 Mvar 35190,61 MVA |
 |
 | Load P(Un-U) = -0,00 MW -0,00 Mvar |
 | Motor Load = 0,00 MW 0,00 Mvar 0,00 MVA |
 | Grid Losses = 739,76 MW -12462,92 Mvar |
 | Line Charging = -20404,94 Mvar |
 | Compensation ind. = 11075,19 Mvar |
 | Compensation cap. = -64,95 Mvar |
 |
 | Installed Capacity = 95326,51 MW |
 | Spinning Reserve = 59716,91 MW |
 |
 | Total Power Factor:
Generation = 1,00 [-]

 --
 | Grid: ES System Stage: ES | Study Case: Study Case | Annex: / 20 |

--
Load/Motor = 1,00 / 0,00 [-]

--
 | Inter Grid Flow to | |
 | PT = 433,70 MW 619,20 Mvar |
 | FR = 2090,71 MW -425,77 Mvar |
 | EU = -8,00 MW -8,00 Mvar |
Total = 2516,41 MW 185,43 Mvar

Grid: EU System Stage: EU | Study Case: Study Case | Annex: / 21

Grid: EU		Summary					
No. of Substations	0	No. of Busbars	837	No. of Terminals	0	No. of Lines	0
No. of 2-w Trfs.	0	No. of 3-w Trfs.	0	No. of syn. Machines	0	No. of	
asyn.Machines	0						
No. of Loads	0	No. of Shunts/Filters	0	No. of SVS	0		
Generation	=	0,00 MW	0,00 Mvar	0,00 MVA			
External Infeed	=	4653,00 MW	-1236,55 Mvar	4814,51 MVA			
Inter Grid Flow	=	4653,00 MW	-1236,55 Mvar				
Load P(U)	=	0,00 MW	0,00 Mvar	0,00 MVA			
Load P(Un)	=	0,00 MW	0,00 Mvar	0,00 MVA			
Load P(Un-U)	=	0,00 MW	0,00 Mvar				
Motor Load	=	0,00 MW	0,00 Mvar	0,00 MVA			
Grid Losses	=	0,00 MW	0,00 Mvar				
Line Charging	=		0,00 Mvar				
Compensation ind.	=		0,00 Mvar				
Compensation cap.	=		0,00 Mvar				
Installed Capacity	=	0,00 MW					
Spinning Reserve	=	0,00 MW					
Total Power Factor:							
Generation	=	0,00 [-]					

Grid: EU System Stage: EU | Study Case: Study Case | Annex: / 22

Load/Motor = 0,00 / 0,00 [-]

Inter Grid Flow to							
CH	=	-50,00 MW	0,02 Mvar				
FR	=	-726,99 MW	-938,12 Mvar				
DE	=	3517,00 MW	67,41 Mvar				
NL	=	700,00 MW	-0,11 Mvar				
PL	=	1100,00 MW	-0,00 Mvar				
RO	=	-150,00 MW	50,00 Mvar				
SK	=	-244,00 MW	-0,00 Mvar				
ES	=	8,00 MW	8,00 Mvar				
BE	=	-102,00 MW	-63,28 Mvar				
DK	=	2626,98 MW	0,00 Mvar				

BG	=	-900,00 MW	0,00 Mvar	
GR	=	-160,00 MW	-36,37 Mvar	
HR	=	50,00 MW	-1,02 Mvar	
IT	=	-566,00 MW	0,00 Mvar	
HU	=	-450,00 MW	-257,38 Mvar	
LU	=	0,00 MW	-65,71 Mvar	
Total	=	4653,00 MW	-1236,55 Mvar	

| Grid: FR System Stage: FR | Study Case: Study Case | Annex: / 23 |

Grid: FR	Summary					
No. of Substations	1685	No. of Busbars	2815	No. of Terminals	0	No. of Lines
2225						
No. of 2-w Trfs.	649	No. of 3-w Trfs.	0	No. of syn. Machines	3501	No. of
asyn.Machines 0						
No. of Loads	2005	No. of Shunts/Filters	393	No. of SVS	7	
Generation	= 77924,53 MW	-612,21 Mvar		77926,93 MVA		
External Infeed	= 0,00 MW	0,00 Mvar		0,00 MVA		
Inter Grid Flow	= 3171,24 MW	1205,83 Mvar				
Load P(U)	= 73435,15 MW	5057,99 Mvar		73609,13 MVA		
Load P(Un)	= 73435,15 MW	5057,99 Mvar		73609,13 MVA		
Load P(Un-U)	= 0,00 MW	-0,00 Mvar				
Motor Load	= 0,00 MW	0,00 Mvar		0,00 MVA		
Grid Losses	= 1318,14 MW	-11125,87 Mvar				
Line Charging	=	-28437,38 Mvar				
Compensation ind.	=	7939,91 Mvar				
Compensation cap.	=	-3690,08 Mvar				
Installed Capacity	= 175873,81 MW					
Spinning Reserve	= 89741,43 MW					
Total Power Factor:						
Generation	= 1,00 [-]					

| Grid: FR System Stage: FR | Study Case: Study Case | Annex: / 24 |

Load/Motor	= 1,00 / 0,00 [-]	
------------	-------------------	--

Inter Grid Flow to			
BE	= -2045,97 MW	160,34 Mvar	
ES	= -2090,71 MW	425,77 Mvar	
CH	= 2023,11 MW	-159,08 Mvar	
IT	= 2693,14 MW	169,49 Mvar	
EU	= 726,99 MW	938,12 Mvar	
DE	= 1755,70 MW	-324,33 Mvar	
LU	= 108,98 MW	-4,48 Mvar	
Total	= 3171,24 MW	1205,83 Mvar	

Grid: GR System Stage: GR | Study Case: Study Case | Annex: / 25

Grid: GR		Summary				
No. of Substations	2191	No. of Busbars	2188	No. of Terminals	1	No. of Lines
1808						
No. of 2-w Trfs.	799	No. of 3-w Trfs.	76	No. of syn. Machines	660	No. of
asyn.Machines	0					
No. of Loads	354	No. of Shunts/Filters	174	No. of SVS	0	
Generation	= 6951,73 MW	-270,90 Mvar		6957,01 MVA		
External Infeed	= 0,00 MW	0,00 Mvar		0,00 MVA		
Inter Grid Flow	= -35,78 MW	11,17 Mvar				
Load P(U)	= 6853,44 MW	3421,63 Mvar		7660,11 MVA		
Load P(Un)	= 6853,44 MW	3421,63 Mvar		7660,11 MVA		
Load P(Un-U)	= 0,00 MW	-0,00 Mvar				
Motor Load	= 0,00 MW	0,00 Mvar		0,00 MVA		
Grid Losses	= 134,07 MW	-6542,34 Mvar				
Line Charging	=	-8307,34 Mvar				
Compensation ind.	=	3314,56 Mvar				
Compensation cap.	=	-475,92 Mvar				
Installed Capacity	= 16111,73 MW					
Spinning Reserve	= 17243,60 MW					
Total Power Factor:						
Generation	= 1,00 [-]					

Grid: GR System Stage: GR | Study Case: Study Case | Annex: / 26

Load/Motor = 0,89 / 0,00 [-]

Inter Grid Flow to			
BG	= -243,06 MW	41,17 Mvar	
AL	= 49,24 MW	-6,41 Mvar	
EU	= 160,00 MW	36,37 Mvar	
MK	= -1,96 MW	-59,96 Mvar	
Total	= -35,78 MW	11,17 Mvar	

Grid: HR System Stage: HR | Study Case: Study Case | Annex: / 27

Grid: HR		Summary			
No. of Substations	226	No. of Busbars	226	No. of Terminals	0
No. of 2-w Trfs. asyn. Machines	39	No. of 3-w Trfs.	0	No. of syn. Machines	93
No. of Loads	331	No. of Shunts/Filters	6	No. of SVS	0
Generation	= 1975,72 MW	-158,74 Mvar	1982,09 MVA		
External Infeed	= 0,00 MW	0,00 Mvar	0,00 MVA		
Inter Grid Flow	= -322,94 MW	1,67 Mvar			
Load P(U)	= 2191,00 MW	358,57 Mvar	2220,15 MVA		
Load P(Un)	= 2191,00 MW	358,57 Mvar	2220,15 MVA		
Load P(Un-U)	= 0,00 MW	0,00 Mvar			
Motor Load	= 0,00 MW	0,00 Mvar	0,00 MVA		
Grid Losses	= 107,65 MW	-518,98 Mvar			
Line Charging	=	-1267,15 Mvar			
Compensation ind.	=	0,00 Mvar			
Compensation cap.	=	0,00 Mvar			
Installed Capacity	= 5684,99 MW				
Spinning Reserve	= 3205,43 MW				
Total Power Factor:					
Generation	= 1,00 [-]				

Grid: HR System Stage: HR | Study Case: Study Case | Annex: / 28

Load/Motor = 0,99 / 0,00 [-]

Inter Grid Flow to			
BA	= -1253,15 MW	201,47 Mvar	
SI	= 802,74 MW	-18,50 Mvar	
HU	= 704,65 MW	-228,71 Mvar	
RS	= -527,18 MW	46,39 Mvar	
EU	= -50,00 MW	1,02 Mvar	
Total	= -322,94 MW	1,67 Mvar	

| Grid: HU System Stage: HU | Study Case: Study Case | Annex: /
29 |

--

Grid: HU	Summary					
No. of Substations	545	No. of Busbars	825	No. of Terminals	0	No. of Lines
792						
No. of 2-w Trfs.	290	No. of 3-w Trfs.	0	No. of syn. Machines	497	No. of
asyn.Machines 0						
No. of Loads	390	No. of Shunts/Filters	40	No. of SVS	0	
Generation	= 4528,60 MW	273,20 Mvar		4536,83 MVA		
External Infeed	= 0,00 MW	0,00 Mvar		0,00 MVA		
Inter Grid Flow	= -1143,49 MW	684,75 Mvar				
Load P(U)	= 5530,28 MW	1064,91 Mvar		5631,88 MVA		
Load P(Un)	= 5530,28 MW	1064,91 Mvar		5631,88 MVA		
Load P(Un-U)	= -0,00 MW	0,00 Mvar				
Motor Load	= 0,00 MW	0,00 Mvar		0,00 MVA		
Grid Losses	= 141,80 MW	-1476,46 Mvar				
Line Charging	=	-2994,80 Mvar				
Compensation ind.	=	0,00 Mvar				
Compensation cap.	=	0,00 Mvar				
Installed Capacity	= 12337,87 MW					
Spinning Reserve	= 6784,90 MW					
Total Power Factor:						
Generation	= 1,00 [-]					

| Grid: HU System Stage: HU | Study Case: Study Case | Annex: /
30 |

--
| Load/Motor = 0,98 / 0,00 [-]

--

Inter Grid Flow to						
SK	= 312,36 MW	-70,14 Mvar				
AT	= 80,10 MW	30,05 Mvar				
SI	= -60,70 MW	58,62 Mvar				
HR	= -704,65 MW	228,71 Mvar				
EU	= 450,00 MW	257,38 Mvar				
RO	= -800,02 MW	121,79 Mvar				
RS	= -420,59 MW	58,35 Mvar				
Total	= -1143,49 MW	684,75 Mvar				

| Grid: IT System Stage: IT | Study Case: Study Case | Annex: / 31 |

Grid: IT		Summary					
No. of Substations	1904	No. of Busbars	1904	No. of Terminals	0	No. of Lines	1038
No. of 2-w Trfs.	1282	No. of 3-w Trfs.	3	No. of syn. Machines	4104	No. of asyn. Machines	0
No. of Loads	1157	No. of Shunts/Filters	101	No. of SVS	0		
Generation	= 38583,09 MW	-1110,36 Mvar		38599,06 MVA			
External Infeed	= 0,00 MW	0,00 Mvar		0,00 MVA			
Inter Grid Flow	= -8129,40 MW	231,23 Mvar					
Load P(U)	= 46249,46 MW	3580,25 Mvar		46387,83 MVA			
Load P(Un)	= 46249,46 MW	3580,25 Mvar		46387,83 MVA			
Load P(Un-U)	= -0,00 MW	-0,00 Mvar					
Motor Load	= 0,00 MW	0,00 Mvar		0,00 MVA			
Grid Losses	= 463,03 MW	-5909,44 Mvar					
Line Charging	=	-13758,60 Mvar					
Compensation ind.	=	2031,70 Mvar					
Compensation cap.	=	-1044,10 Mvar					
Installed Capacity	= 123439,81 MW						
Spinning Reserve	= 80817,17 MW						
Total Power Factor:							
Generation	=	1,00 [-]					

| Grid: IT System Stage: IT | Study Case: Study Case | Annex: / 32 |

| Load/Motor = 1,00 / 0,00 [-]

Inter Grid Flow to			
AT	= -863,16 MW	100,88 Mvar	
CH	= -4484,76 MW	445,20 Mvar	
FR	= -2693,14 MW	-169,49 Mvar	
SI	= -987,34 MW	76,09 Mvar	
EU	= 566,00 MW	-0,00 Mvar	
ME	= 333,01 MW	-221,45 Mvar	
Total	= -8129,40 MW	231,23 Mvar	

--
 | Grid: LU System Stage: LU | Study Case: Study Case | Annex: / 33
 |

--
 | Grid: LU Summary
 |
 | No. of Substations 37 No. of Busbars 46 No. of Terminals 0 No. of Lines
 45 |
 | No. of 2-w Trfs. 14 No. of 3-w Trfs. 0 No. of syn. Machines 23 No. of
 asyn.Machines 0 |
 | No. of Loads 28 No. of Shunts/Filters 0 No. of SVS 0 |
 |
 | Generation = 155,24 MW -222,86 Mvar 271,60 MVA |
 | External Infeed = 0,00 MW 0,00 Mvar 0,00 MVA |
 | Inter Grid Flow = -984,65 MW -193,33 Mvar |
 | Load P(U) = 1127,97 MW 70,01 Mvar 1130,14 MVA |
 | Load P(Un) = 1127,97 MW 70,01 Mvar 1130,14 MVA |
 |
 | Load P(Un-U) = -0,00 MW -0,00 Mvar |
 | Motor Load = 0,00 MW 0,00 Mvar 0,00 MVA |
 | Grid Losses = 11,93 MW -99,54 Mvar |
 | Line Charging = -196,98 Mvar |
 | Compensation ind. = 0,00 Mvar |
 | Compensation cap. = 0,00 Mvar |
 |
 | Installed Capacity = 2119,50 MW |
 | Spinning Reserve = 1954,26 MW |
 |
 | Total Power Factor:
 | Generation = 0,57 [-] |
 |

--
 | Grid: LU System Stage: LU | Study Case: Study Case | Annex: / 34
 |

--
 | Load/Motor = 1,00 / 0,00 [-] |
 |

--
 | Inter Grid Flow to
 | EU = -0,00 MW 65,71 Mvar |
 | BE = 262,01 MW -58,90 Mvar |
 | DE = -1137,68 MW -204,61 Mvar |
 | FR = -108,98 MW 4,48 Mvar |
 | Total = -984,65 MW -193,33 Mvar |
 |

| Grid: ME System Stage: ME | Study Case: Study Case | Annex: /
35 |

--

Grid: ME	Summary						
No. of Substations	145	No. of Busbars	248	No. of Terminals	0	No. of Lines	
112							
No. of 2-w Trfs.	31	No. of 3-w Trfs.	79	No. of syn. Machines	31	No. of	
asyn.Machines 0							
No. of Loads	80	No. of Shunts/Filters	0	No. of SVS	0		
Generation	= 453,91 MW	73,07 Mvar		459,75 MVA			
External Infeed	= 0,00 MW	0,00 Mvar		0,00 MVA			
Inter Grid Flow	= -91,40 MW	213,29 Mvar					
Load P(U)	= 534,85 MW	176,52 Mvar		563,22 MVA			
Load P(Un)	= 534,85 MW	176,52 Mvar		563,22 MVA			
Load P(Un-U)	= -0,00 MW	-0,00 Mvar					
Motor Load	= 0,00 MW	0,00 Mvar		0,00 MVA			
Grid Losses	= 10,46 MW	-316,74 Mvar					
Line Charging	=	-446,18 Mvar					
Compensation ind.	=	0,00 Mvar					
Compensation cap.	=	0,00 Mvar					
Installed Capacity	= 1742,28 MW						
Spinning Reserve	= 1227,59 MW						
Total Power Factor:							
Generation	= 0,99 [-]						

--

| Grid: ME System Stage: ME | Study Case: Study Case | Annex: /
36 |

--

| Load/Motor = 0,95 / 0,00 [-]

--

Inter Grid Flow to						
BA	= 73,22 MW	21,54 Mvar				
AL	= -62,62 MW	20,02 Mvar				
RS	= 231,01 MW	-49,72 Mvar				
IT	= -333,01 MW	221,45 Mvar				
Total	= -91,40 MW	213,29 Mvar				

| Grid: MK System Stage: MK | Study Case: Study Case | Annex: /
37 |

--

Grid: MK	Summary					
No. of Substations	125	No. of Busbars	144	No. of Terminals	0	No. of Lines
155						
No. of 2-w Trfs.	27	No. of 3-w Trfs.	18	No. of syn. Machines	36	No. of
asyn.Machines 0						
No. of Loads	100	No. of Shunts/Filters	6	No. of SVS	0	
Generation	= 1189,41 MW	44,89 Mvar		1190,26 MVA		
External Infeed	= 0,00 MW	0,00 Mvar		0,00 MVA		
Inter Grid Flow	= 0,06 MW	-47,22 Mvar				
Load P(U)	= 1174,10 MW	402,41 Mvar		1241,15 MVA		
Load P(Un)	= 1174,10 MW	402,41 Mvar		1241,15 MVA		
Load P(Un-U)	= 0,00 MW	0,00 Mvar				
Motor Load	= 0,00 MW	0,00 Mvar		0,00 MVA		
Grid Losses	= 15,25 MW	-310,30 Mvar				
Line Charging	=	-487,12 Mvar				
Compensation ind.	=	0,00 Mvar				
Compensation cap.	=	0,00 Mvar				
Installed Capacity	= 1008,50 MW					
Spinning Reserve	= 265,39 MW					
Total Power Factor:						
Generation	= 1,00 [-]					

--

| Grid: MK System Stage: MK | Study Case: Study Case | Annex: /
38 |

--

| Load/Motor = 0,95 / 0,00 [-]

--

Inter Grid Flow to						
GR	= 1,96 MW	59,96 Mvar				
BG	= -6,25 MW	-24,76 Mvar				
RS	= -89,68 MW	-102,57 Mvar				
AL	= 94,02 MW	20,15 Mvar				
Total	= 0,06 MW	-47,22 Mvar				

Grid: NL System Stage: NL | Study Case: Study Case | Annex: / 39

--

Grid: NL	Summary					
No. of Substations	967	No. of Busbars	705	No. of Terminals	953	No. of Lines
1228						
No. of 2-w Trfs.	445	No. of 3-w Trfs.	208	No. of syn. Machines	732	No. of
asyn.Machines	0					
No. of Loads	327	No. of Shunts/Filters	168	No. of SVS	0	
Generation	= 17363,54 MW	-2310,48 Mvar		17516,59 MVA		
External Infeed	= 0,00 MW	0,00 Mvar		0,00 MVA		
Inter Grid Flow	= 908,59 MW	-1165,20 Mvar				
Load P(U)	= 16177,00 MW	4897,99 Mvar		16902,24 MVA		
Load P(Un)	= 16177,00 MW	4897,99 Mvar		16902,24 MVA		
Load P(Un-U)	= -0,00 MW	-0,00 Mvar				
Motor Load	= 0,00 MW	0,00 Mvar		0,00 MVA		
Grid Losses	= 277,95 MW	-6118,88 Mvar				
Line Charging	=	-10887,15 Mvar				
Compensation ind.	=	4074,92 Mvar				
Compensation cap.	=	-3999,30 Mvar				
Installed Capacity	= 532844,57 MW					
Spinning Reserve	= 24877,26 MW					
Total Power Factor:						
Generation	= 0,99 [-]					

--

Grid: NL System Stage: NL | Study Case: Study Case | Annex: / 40

Load/Motor = 0,96 / 0,00 [-]

--

Inter Grid Flow to			
DE	= 207,54 MW	-427,36 Mvar	
BE	= 1401,05 MW	-737,95 Mvar	
EU	= -700,00 MW	0,11 Mvar	
Total	= 908,59 MW	-1165,20 Mvar	

| Grid: PL System Stage: PL | Study Case: Study Case | Annex: / 41 |

--

Grid: PL		Summary					
No. of Substations	293	No. of Busbars	369	No. of Terminals	0	No. of Lines	393
No. of 2-w Trfs.	232	No. of 3-w Trfs.	14	No. of syn. Machines	1017	No. of asyn. Machines	0
No. of Loads	175	No. of Shunts/Filters	51	No. of SVS	0		
Generation	= 22818,15 MW	1325,96 Mvar		22856,64 MVA			
External Infeed	= -0,00 MW	1855,26 Mvar		1855,26 MVA			
Inter Grid Flow	= -3073,98 MW	94,84 Mvar					
Load P(U)	= 25600,74 MW	5418,90 Mvar		26167,97 MVA			
Load P(Un)	= 25600,74 MW	5418,90 Mvar		26167,97 MVA			
Load P(Un-U)	= -0,00 MW	-0,00 Mvar					
Motor Load	= 0,00 MW	0,00 Mvar		0,00 MVA			
Grid Losses	= 291,39 MW	-3039,12 Mvar					
Line Charging	=	-6663,66 Mvar					
Compensation ind.	=	824,08 Mvar					
Compensation cap.	=	-117,48 Mvar					
Installed Capacity	= 52280,55 MW						
Spinning Reserve	= 23255,65 MW						
Total Power Factor:							
Generation	= 1,00 [-]						

| Grid: PL System Stage: PL | Study Case: Study Case | Annex: / 42 |

--

Load/Motor	= 0,98 / 0,00 [-]
------------	-------------------

--

Inter Grid Flow to	
CZ	= -59,04 MW 193,25 Mvar
EU	= -1100,00 MW 0,00 Mvar
DE	= -1940,66 MW -110,89 Mvar
SK	= 25,72 MW 12,48 Mvar
Total	= -3073,98 MW 94,84 Mvar

| Grid: PT System Stage: PT | Study Case: Study Case | Annex: / 43 |

Grid: PT	Summary					
No. of Substations	574	No. of Busbars	605	No. of Terminals	0	No. of Lines
606						
No. of 2-w Trfs.	335	No. of 3-w Trfs.	0	No. of syn. Machines	297	No. of
asyn.Machines 0						
No. of Loads	91	No. of Shunts/Filters	68	No. of SVS	0	
Generation	= 6538,09 MW	-1200,58 Mvar		6647,40 MVA		
External Infeed	= 0,00 MW	0,00 Mvar		0,00 MVA		
Inter Grid Flow	= -433,70 MW	-619,20 Mvar				
Load P(U)	= 6817,70 MW	1187,70 Mvar		6920,38 MVA		
Load P(Un)	= 6817,70 MW	1187,70 Mvar		6920,38 MVA		
Load P(Un-U)	= -0,00 MW	-0,00 Mvar				
Motor Load	= 0,00 MW	0,00 Mvar		0,00 MVA		
Grid Losses	= 154,09 MW	-1559,36 Mvar				
Line Charging	=	-3184,02 Mvar				
Compensation ind.	=	0,00 Mvar				
Compensation cap.	=	-209,72 Mvar				
Installed Capacity	= 27061,90 MW					
Spinning Reserve	= 18756,01 MW					
Total Power Factor:						
Generation	= 0,98 [-]					

| Grid: PT System Stage: PT | Study Case: Study Case | Annex: / 44 |

| Load/Motor = 0,99 / 0,00 [-] |

Inter Grid Flow to						
ES	= -433,70 MW	-619,20 Mvar				
Total	= -433,70 MW	-619,20 Mvar				

Grid: RO System Stage: RO | Study Case: Study Case | Annex: / 45

Grid: RO		Summary				
No. of Substations	115	No. of Busbars	128	No. of Terminals	0	No. of Lines
186						
No. of 2-w Trfs.	36	No. of 3-w Trfs.	0	No. of syn. Machines	156	No. of
asyn.Machines	0					
No. of Loads	88	No. of Shunts/Filters	15	No. of SVS	0	
Generation	=	9928,23 MW	-701,08 Mvar	9952,95 MVA		
External Infeed	=	0,00 MW	0,00 Mvar	0,00 MVA		
Inter Grid Flow	=	1507,42 MW	-310,07 Mvar			
Load P(U)	=	8281,99 MW	2598,27 Mvar	8680,00 MVA		
Load P(Un)	=	8281,99 MW	2598,27 Mvar	8680,00 MVA		
Load P(Un-U)	=	0,00 MW	0,00 Mvar			
Motor Load	=	0,00 MW	0,00 Mvar	0,00 MVA		
Grid Losses	=	138,81 MW	-2989,28 Mvar			
Line Charging	=		-4281,21 Mvar			
Compensation ind.	=		0,00 Mvar			
Compensation cap.	=		0,00 Mvar			
Installed Capacity	=	19431,50 MW				
Spinning Reserve	=	7666,24 MW				
Total Power Factor:						
Generation	=	1,00 [-]				

Grid: RO System Stage: RO | Study Case: Study Case | Annex: / 46

Load/Motor = 0,95 / 0,00 [-]

Inter Grid Flow to			
RS	=	-192,72 MW	-26,60 Mvar
EU	=	150,00 MW	-50,00 Mvar
BG	=	750,13 MW	-111,68 Mvar
HU	=	800,02 MW	-121,79 Mvar
Total	=	1507,42 MW	-310,07 Mvar

Grid: RS	System Stage: RS	Study Case: Study Case	Annex: / 47
Grid: RS	Summary		
No. of Substations	1029	No. of Busbars	1373
No. of Terminals	0	No. of Lines	798
No. of 2-w Trfs.	502	No. of 3-w Trfs.	318
No. of syn. Machines	105	No. of asyn. Machines	0
No. of Loads	405	No. of Shunts/Filters	0
No. of SVS	0		
Generation	= 6505,97 MW	1435,03 Mvar	6662,35 MVA
External Infeed	= 0,00 MW	0,00 Mvar	0,00 MVA
Inter Grid Flow	= 484,56 MW	195,56 Mvar	
Load P(U)	= 5869,78 MW	1313,06 Mvar	6014,85 MVA
Load P(Un)	= 5869,78 MW	1313,06 Mvar	6014,85 MVA
Load P(Un-U)	= -0,00 MW	-0,00 Mvar	
Motor Load	= 0,00 MW	0,00 Mvar	0,00 MVA
Grid Losses	= 151,63 MW	-73,59 Mvar	
Line Charging	=	-1956,19 Mvar	
Compensation ind.	=	0,00 Mvar	
Compensation cap.	=	0,00 Mvar	
Installed Capacity	= 8546,36 MW		
Spinning Reserve	= 3677,50 MW		
Total Power Factor:			
Generation	= 0,98 [-]		

Grid: RS	System Stage: RS	Study Case: Study Case	Annex: / 48
----------	------------------	------------------------	-------------

Load/Motor = 0,98 / 0,00 [-]

Inter Grid Flow to			
BA	= -176,39 MW	112,77 Mvar	
HR	= 527,18 MW	-46,39 Mvar	
AL	= -136,84 MW	-9,96 Mvar	
RO	= 192,72 MW	26,60 Mvar	
ME	= -231,01 MW	49,72 Mvar	
HU	= 420,59 MW	-58,35 Mvar	
MK	= 89,68 MW	102,57 Mvar	
BG	= -201,37 MW	18,60 Mvar	
Total	= 484,56 MW	195,56 Mvar	

| Grid: SI System Stage: SI | Study Case: Study Case | Annex: / 49 |

Grid: SI		Summary				
No. of Substations	169	No. of Busbars	175	No. of Terminals	0	No. of Lines
283						
No. of 2-w Trfs.	29	No. of 3-w Trfs.	0	No. of syn. Machines	97	No. of
asyn.Machines	0					
No. of Loads	157	No. of Shunts/Filters	3	No. of SVS	1	
Generation	= 2484,20 MW	-350,39 Mvar		2508,79 MVA		
External Infeed	= 0,00 MW	0,00 Mvar		0,00 MVA		
Inter Grid Flow	= 339,21 MW	-328,19 Mvar				
Load P(U)	= 2108,25 MW	315,50 Mvar		2131,72 MVA		
Load P(Un)	= 2108,25 MW	315,50 Mvar		2131,72 MVA		
Load P(Un-U)	= -0,00 MW	-0,00 Mvar				
Motor Load	= 0,00 MW	0,00 Mvar		0,00 MVA		
Grid Losses	= 36,74 MW	-295,86 Mvar				
Line Charging	=	-700,35 Mvar				
Compensation ind.	=	47,12 Mvar				
Compensation cap.	=	-88,97 Mvar				
Installed Capacity	= 4108,34 MW					
Spinning Reserve	= 1527,69 MW					
Total Power Factor:						
Generation	= 0,99 [-]					

| Grid: SI System Stage: SI | Study Case: Study Case | Annex: / 50 |

Load/Motor	= 0,99 / 0,00 [-]
------------	-------------------

Inter Grid Flow to	
HU	= 60,70 MW -58,62 Mvar
HR	= -802,74 MW 18,50 Mvar
IT	= 987,34 MW -76,09 Mvar
AT	= 93,91 MW -211,97 Mvar
Total	= 339,21 MW -328,19 Mvar

| Grid: SK System Stage: SK | Study Case: Study Case | Annex: / 51

--

Grid: SK	Summary					
No. of Substations	29	No. of Busbars	34	No. of Terminals	0	No. of Lines
53						
No. of 2-w Trfs.	0	No. of 3-w Trfs.	1	No. of syn. Machines	109	No. of
asyn.Machines 0						
No. of Loads	21	No. of Shunts/Filters	24	No. of SVS	0	
Generation	= 4053,52 MW	104,84 Mvar		4054,88 MVA		
External Infeed	= 0,00 MW	0,00 Mvar		0,00 MVA		
Inter Grid Flow	= -617,51 MW	225,56 Mvar				
Load P(U)	= 4642,00 MW	1083,00 Mvar		4766,66 MVA		
Load P(Un)	= 4642,00 MW	1083,00 Mvar		4766,66 MVA		
Load P(Un-U)	= 0,00 MW	0,00 Mvar				
Motor Load	= 0,00 MW	0,00 Mvar		0,00 MVA		
Grid Losses	= 29,04 MW	-1203,72 Mvar				
Line Charging	=	-1540,66 Mvar				
Compensation ind.	=	0,00 Mvar				
Compensation cap.	=	0,00 Mvar				
Installed Capacity	= 6141,00 MW					
Spinning Reserve	= 2087,48 MW					
Total Power Factor:						
Generation	= 1,00 [-]					

--

| Grid: SK System Stage: SK | Study Case: Study Case | Annex: / 52

| Load/Motor = 0,97 / 0,00 [-]

--

Inter Grid Flow to						
HU	= -312,36 MW	70,14 Mvar				
PL	= -25,72 MW	-12,48 Mvar				
CZ	= -523,43 MW	167,90 Mvar				
EU	= 244,00 MW	0,00 Mvar				
Total	= -617,51 MW	225,56 Mvar				

The number of overloaded lines (loading over 100% rated thermal capacity) for this snapshot is 30.

6.1.2 Baltics Synchronous area

It is possible with the assembled model to run a load flow study with reactive limits enabled.

On this model 3 slacks are used for the Baltics model.

4884_1 LV
5820_1(1) LT
7013_9 EE

It is recommended to set the HVDC exchanges to the same values in both sides of the interconnections. The model converges in 11 iterations with the selected slacks and the recommended settings.

In case of inserting a model of the HVDC link, the balances of the EquivalentInjections indicated on both sides of the link should be maintained to keep the balances.

The results for load flow are shown below:

Load Flow Calculation		Grid Summary	
AC Load Flow, balanced, positive sequence		Automatic Model Adaptation for Convergence	
No			
Automatic tap adjustment of transformers		No	Max. Acceptable Load Flow Error
Consider reactive power limits		Yes	Bus Equations(HV) 1,00 kVA
		Model Equations	0,10 %
Grid: EE00		System Stage: EE00	Study Case: Study Case Annex: /
1			
Grid: EE00		Summary	
No. of Substations		264	No. of Busbars 385
334			No. of Terminals 0
No. of 2-w Trfs.		27	No. of 3-w Trfs. 26
asyn.Machines 0			No. of syn. Machines 36
No. of Loads		191	No. of Shunts/Filters 37
			No. of SVS 0
Generation		= 1308,35 MW	118,88 Mvar 1313,74 MVA
External Infeed		= 0,00 MW	0,00 Mvar 0,00 MVA
Inter Grid Flow		= -27,16 MW	-71,13 Mvar
Load P(U)		= 1234,21 MW	234,98 Mvar 1256,38 MVA
Load P(Un)		= 1234,21 MW	234,98 Mvar 1256,38 MVA
Load P(Un-U)		= -0,00 MW	-0,00 Mvar
Motor Load		= 0,00 MW	0,00 Mvar 0,00 MVA
Grid Losses		= 101,30 MW	-603,50 Mvar
Line Charging		=	-1221,27 Mvar
Compensation ind.		=	871,30 Mvar
Compensation cap.		=	-312,77 Mvar
Installed Capacity		= 2364,98 MW	
Spinning Reserve		= 516,85 MW	
Total Power Factor:			
Generation		= 1,00 [-]	
Load/Motor		= 0,98 / 0,00 [-]	

Grid: EE00	System Stage: EE00	Study Case: Study Case	Annex: /
2			

--

Inter Grid Flow to			
LV00	= 540,84 MW	-71,13 Mvar	
EU	= -568,00 MW	-0,00 Mvar	
Total	= -27,16 MW	-71,13 Mvar	

Load Flow Calculation	Grid Summary		
-----------------------	--------------	--	--

--

AC Load Flow, balanced, positive sequence	No	Automatic Model Adaptation for Convergence	
Automatic tap adjustment of transformers	No	Max. Acceptable Load Flow Error	
Consider reactive power limits	Yes	Bus Equations(HV)	1,00 kVA
		Model Equations	0,10 %

--

Grid: EU	System Stage: EU	Study Case: Study Case	Annex: /
3			

--

Grid: EU Summary							
No. of Substations	0	No. of Busbars	837	No. of Terminals	0	No. of Lines	0
No. of 2-w Trfs.	0	No. of 3-w Trfs.	0	No. of syn. Machines	0	No. of	
asyn.Machines	0						
No. of Loads	0	No. of Shunts/Filters	0	No. of SVS	0		
Generation	= 0,00 MW	0,00 Mvar		0,00 MVA			
External Infeed	= 1065,00 MW	-0,00 Mvar		1065,00 MVA			
Inter Grid Flow	= 1065,00 MW	0,00 Mvar					
Load P(U)	= 0,00 MW	0,00 Mvar		0,00 MVA			
Load P(Un)	= 0,00 MW	0,00 Mvar		0,00 MVA			
Load P(Un-U)	= 0,00 MW	0,00 Mvar					
Motor Load	= 0,00 MW	0,00 Mvar		0,00 MVA			
Grid Losses	= 0,00 MW	0,00 Mvar					

Line Charging	=	0,00	Mvar	
Compensation ind.	=	0,00	Mvar	
Compensation cap.	=	0,00	Mvar	
Installed Capacity	=	0,00	MW	
Spinning Reserve	=	0,00	MW	
Total Power Factor:				
Generation	=	0,00	[-]	
Load/Motor	=	0,00 / 0,00	[-]	

--

Grid: EU	System Stage: EU	Study Case: Study Case	Annex: / 4
----------	------------------	------------------------	------------

Inter Grid Flow to				
EE00	=	568,00	MW	0,00 Mvar
LT00	=	497,00	MW	0,00 Mvar
Total	=	1065,00	MW	0,00 Mvar

Load Flow Calculation		Grid Summary		
AC Load Flow, balanced, positive sequence	No	Automatic Model Adaptation for Convergence		
Automatic tap adjustment of transformers	No	Max. Acceptable Load Flow Error		
Consider reactive power limits	Yes	Bus Equations(HV)	1,00 kVA	
		Model Equations	0,10 %	

--

Grid: LT00	System Stage: LT00	Study Case: Study Case	Annex: / 5
------------	--------------------	------------------------	------------

Grid: LT00	Summary					
No. of Substations	448	No. of Busbars	560	No. of Terminals	0	No. of Lines
592						

No. of 2-w Trfs. asyn.Machines	77	No. of 3-w Trfs.	0	No. of syn. Machines	41	No. of	
No. of Loads	458	No. of Shunts/Filters	15	No. of SVS	0		
Generation	= 772,95 MW	-121,09 Mvar		782,37 MVA			
External Infeed	= 0,00 MW	0,00 Mvar		0,00 MVA			
Inter Grid Flow	= -1162,21 MW	72,88 Mvar					
Load P(U)	= 1908,99 MW	496,82 Mvar		1972,58 MVA			
Load P(Un)	= 1908,99 MW	496,82 Mvar		1972,58 MVA			
Load P(Un-U)	= -0,00 MW	-0,00 Mvar					
Motor Load	= 0,00 MW	0,00 Mvar		0,00 MVA			
Grid Losses	= 26,16 MW	-1029,98 Mvar					
Line Charging	=	-1229,38 Mvar					
Compensation ind.	=	339,19 Mvar					
Compensation cap.	=	0,00 Mvar					
Installed Capacity	= 2893,03 MW						
Spinning Reserve	= 1682,05 MW						
Total Power Factor:							
Generation	= 0,99 [-]						
Load/Motor	= 0,97 / 0,00 [-]						

--

Grid: LT00	System Stage: LT00	Study Case: Study Case	Annex: /
------------	--------------------	------------------------	----------

6 |

--

Inter Grid Flow to			
LV00	= -665,21 MW	72,88 Mvar	
EU	= -497,00 MW	-0,00 Mvar	
Total	= -1162,21 MW	72,88 Mvar	

Load Flow Calculation		Grid Summary	
AC Load Flow, balanced, positive sequence		Automatic Model Adaptation for Convergence	
No			
Automatic tap adjustment of transformers		No	Max. Acceptable Load Flow Error
Consider reactive power limits		Yes	Bus Equations(HV) 1,00 kVA
		Model Equations	0,10 %
Grid: LV00		System Stage: LV00	Study Case: Study Case Annex: /
7			
Grid: LV00		Summary	
No. of Substations		299	No. of Busbars 299
No. of 2-w Trfs.		68	No. of 3-w Trfs. 0
No. of asyn.Machines		0	No. of syn. Machines 40
No. of Loads		154	No. of Shunts/Filters 6
			No. of SVS 0
Generation		= 1263,00 MW	-402,90 Mvar 1325,71 MVA
External Infeed		= 0,00 MW	0,00 Mvar 0,00 MVA
Inter Grid Flow		= 124,37 MW	-1,75 Mvar
Load P(U)		= 1109,00 MW	438,89 Mvar 1192,69 MVA
Load P(Un)		= 1109,00 MW	438,89 Mvar 1192,69 MVA
Load P(Un-U)		= 0,00 MW	-0,00 Mvar
Motor Load		= 0,00 MW	0,00 Mvar 0,00 MVA
Grid Losses		= 29,63 MW	-840,04 Mvar
Line Charging		=	-1129,21 Mvar
Compensation ind.		=	0,00 Mvar
Compensation cap.		=	0,00 Mvar
Installed Capacity		= 4350,55 MW	
Spinning Reserve		= 123,00 MW	
Total Power Factor:			
Generation		= 0,95 [-]	
Load/Motor		= 0,93 / 0,00 [-]	

--			
Grid: LV00	System Stage: LV00	Study Case: Study Case	Annex: /
8			

--			

--			
Inter Grid Flow to			
LT00	= 665,21 MW	-72,88 Mvar	
EE00	= -540,84 MW	71,13 Mvar	
Total	= 124,37 MW	-1,75 Mvar	

The number of overloaded lines (loading over 100% rated thermal capacity) for this snapshot is 18.

6.2 Contingency analysis

It is possible to run a N-1 contingency analysis for all lines.

6.2.1 CE Synchronous area

The results show there are 57 elements with an overload exceeding 100%.

6.2.2 Baltics Synchronous area

The results are shown below:

The results show there are 25 elements with an overload exceeding 100%.

6.3 Short circuit study

The information for all generators is not present in the NT2025_CE model.

It is possible with the assembled model to run a 3-phase short circuit study, with standard values for each generation type.

6.4 Other studies

In case of use of the model for other studies, the dynamic data is not part of the NT2025_CE model. As all generating units are categorized and the rated power is available, it would be possible for the user to insert a dynamic model for a particular grid and insert dynamic data for the rest of the generators.

7. References

[1] TYNDP 2020

<https://tyndp.entsoe.eu/>

[2] Common Information Model

<https://www.entsoe.eu/digital/common-information-model/>

8. Notes

[1] CE and Baltics are connected through a AC X-node. However, the main exchanges are managed through an HVDC line. For the integrity of the studies, CE and Baltics should be considered two separate Synchronous areas.

[2] LU loads have been modelled as voltage dependent. It is recommended to disable the load voltage dependency on the solution.

[3] Tie lines between BA and HR.

There are for instances for boundary node XMO_ZA21. The correct boundary node is XMO_ZA21 as described below.

Attribute	Type	Value
ID	ID	_5d7285b0-73d6-4090-9e84-21a39845a17a
PATH	PATH	EU/ENTSO-E/Mostar-Zakucac/XMO_ZA21
IdentifiedObject.name	String	XMO_ZA21
IdentifiedObject.description	String	XMO_ZA21; overheadLine; 220 kV; BA-HR; Mostar - Zakucac
IdentifiedObject.mRID	String	
IdentifiedObject.shortName	String	XMO_ZA21
IdentifiedObject.energyIdentCodeEic	String	
TopologicalNode.ConnectivityNodeContainer	ConnectivityNodeContainer (Line)	Mostar-Zakucac
TopologicalNode.BaseVoltage	BaseVoltage	AC-220
TopologicalNode.ReportingGroup	ReportingGroup	
TopologicalNode.fromEndIsoCode	String	BA
TopologicalNode.fromEndName	String	Mostar
TopologicalNode.fromEndNameTso	String	NOS BiH
TopologicalNode.toEndIsoCode	String	HR
TopologicalNode.toEndName	String	Zakucac
TopologicalNode.toEndNameTso	String	HOPS
TopologicalNode.boundaryPoint	Boolean	true

Connect BA line XMO_ZA21_WRPJAB2_1_220 to XMO_ZA21 above and substation 56 in BA grid.

Attribute	Type	Value
PATH	PATH	XMO_ZA21_WRPJAB2_1_220
IdentifiedObject.name	String	XMO_ZA21_WRPJAB2_1_220
IdentifiedObject.description	String	_AC_13204_133220_CKT_1- MeteredEnd:13204
ConductingEquipment.BaseVoltage	BaseVoltage	_7891a026ba2c42098556665efd13ba94
ACLLineSegment.r	Resistance	5.159924
ACLLineSegment.x	Reactance	28.121851
ACLLineSegment.bch	Susceptance	0.000167768609
Equipment.aggregate	Boolean	true
Conductor.length	Length	64.5

Ratings:

	name	description	value
XMO_ZA21_WRPJAB2_1_220/_T_AC_13204_1_33220/_OLS1_13204_133220_1/_CL_PATL_13204_133220_1	_CL_PATL_13204_133220_1	RateA	789.920166
XMO_ZA21_WRPJAB2_1_220/_T_AC_13204_1_33220/_OLS2_13204_133220_1/_CL_PATL_13204_133220_1	_CL_PATL_13204_133220_1	RateA	789.920166

There are two instances for XVR_LJ51.

The correct boundary node is XVR_LJ51 as described below.

Attribute	Type	Value
ID	ID	_30c84067-ee6b-465f-bdd9-8a9cd8f
PATH	PATH	EU/ENTSO-E/Vrgorac-Ljubuski/XVR_LJ51
IdentifiedObject.name	String	XVR_LJ51
IdentifiedObject.description	String	XVR_LJ51; overheadLine; 110 kV; BA-HR; TS VRGORAC - TS LJUBUSKI
IdentifiedObject.shortName	String	XVR_LJ51
TopologicalNode.ConnectivityNodeContainer	ConnectivityNodeContainer (Line)	Vrgorac-Ljubuski
TopologicalNode.BaseVoltage	BaseVoltage	AC-110
TopologicalNode.fromEndIsoCode	String	BA
TopologicalNode.fromEndName	String	TS LJUBUSKI
TopologicalNode.fromEndNameTso	String	NOS BiH
TopologicalNode.toEndIsoCode	String	HR
TopologicalNode.toEndName	String	TS VRGORAC
TopologicalNode.toEndNameTso	String	HOPS
TopologicalNode.boundaryPoint	Boolean	true

Connect BA line XVR_LJ51_WLJUBU5_1_110 to XVR_LJ51 above and Substation 69 in BA grid.

Attribute	Type	Value
PATH	PATH	XVR_LJ51_WLJUBU5_1_110
IdentifiedObject.name	String	XVR_LJ51_WLJUBU5_1_110
IdentifiedObject.description	String	_AC_13535_138100_CKT_1-MeteredEnd:138100
ConductingEquipment.BaseVoltage	BaseVoltage	b8e17237e0ca4fca9e4e285b80ab30d0
ACLineSegment.r	Resistance	1.37456
ACLineSegment.x	Reactance	4.55536
ACLineSegment.bch	Susceptance	3.2396696E-05
Equipment.aggregate	Boolean	true
Conductor.length	Length	11.36

Attribute	Type	Value
ID	ID	f03f92e8-dec5-eacf-0848-a39c9ca5f43d
PATH	PATH	AC-110/XVR_LJ51_WLJUBU5_1_110/_T_AC_13535_138100/_OLS1_13535_138100_1/_CL_PATL_13535_138100_1
IdentifiedObject.name	String	_CL_PATL_13535_138100_1
IdentifiedObject.description	String	RateA
CurrentLimit.value	CurrentFlow	645.5826
OperationalLimitSet	OperationalLimitSet	_OLS1_13535_138100_1
OperationalLimitType	OperationalLimitType	PATL

[4] Mismatches on X-nodes correction.

XCA_ME21 CH\Mese (-50+j -0 MVA) IT_19358fed-5a1b-40f7-9064-144596b(0+j 0MVA)XCA_ME21; overheadLine; 220 kV; CH-IT; Castasegna – Mese

Set XCA_ME21 EquivalentInjections to 0 MW.

XBW_BJ1D DE\RAND 380 1D (0+j 67 MVA)
XBW_BJ1D; highVoltageDirectCurrent; 380 kV; DE-DK; Bentwisch – Bjaeverskov

XBW_BJ1K DK\BoundaryInjectionEq(20) (-585+j -0MVA)
XBW_BJ1K; highVoltageDirectCurrent; 400 kV; DK-DE; Bjaeverskov – Bentwisch

Set XBW_BJD and XBW_BJ1K EquivalentInjections to -585 and 585 MW.