

**Indicative values for Net Transfer Capacities ( NTC ) in Europe  
Winter 2002/2003, working day, peak hours  
(Non binding values)**

<b>FROM</b>	<b>TO</b>	<b>MW</b>	<b>VALUE PROVIDED BY</b>
Albania	Greece	<b>250</b>	Greece
Albania+Bulgaria+JIEL	Greece	<b>600</b>	Greece
Austria	Czech Rep.	<b>400</b>	Czech Rep.
	Czech Rep.+Hungary	<b>1100</b>	Austria
	Germany	<b>1500</b>	Germany
	Germany + Switzerland	<b>3000//1400</b>	Switzerland//Austria
	Hungary	<b>100</b>	Hungary
	Italy	<b>220</b>	Austria and Italy
	Slovenia	<b>600-800//800</b>	Austria//Slovenia
Belgium	France	<b>2650</b>	Belgium
	Netherlands	<b>2950</b>	Belgium
Belgium + Germany	Netherlands	<b>4600</b>	Netherlands
Czech Rep. + Poland	Germany	<b>2500//2700</b>	Germany//Poland
Czech Rep. + Hungary	Austria	<b>600-800</b>	Austria
Czech Rep.	Austria	<b>1170</b>	Czech Rep.
	Germany	<b>2320</b>	Czech Rep.
	Poland	<b>800//550</b>	Czech Rep.//Poland
	Slovakia	<b>1740//1100</b>	Czech Rep.//Slovakia
Denmark (West)	Germany	<b>1200</b>	Denmark and Germany
Denmark (East)	Germany	<b>550</b>	Denmark and Germany
Denmark (West)	Sweden	<b>610</b>	Denmark and Sweden
Denmark (East)	Sweden	<b>1700</b>	Denmark and Sweden
Denmark (West)	Norway	<b>950</b>	Denmark and Norway
Finland	Sweden	<b>1650</b>	Finland and Sweden
	Norway	<b>100</b>	Finland and Norway
France	Belgium	<b>2850</b>	Belgium
	Belgium + Germany	<b>4200</b>	France
	Germany	<b>5000</b>	Germany
	Italy	<b>2600</b>	Italy
	Switzerland + Italy	<b>5350//4950</b>	France//Switzerland
	Spain	<b>1400</b>	France and Spain
	United Kingdom	<b>2000</b>	France and United Kingdom
France+Switzerland	Italy	<b>5400</b>	France, Italy and Switzerland

These indicative values have been computed by extrapolation from standard situations, in order to evaluate the transfer capacity through a single interface at the same time. Thus these figures should be considered separately and are not cumulative. When the evaluation of a transfer limit requires to use a set of assumption which are too far from usual or foreseeable situation (leading to high inaccuracies), the NTC figure has been replaced by « no realistic limit ».

FROM	TO	MW	VALUE PROVIDED BY
Germany	Austria	1200	Germany
	Czech Rep.	700	Czech. Rep.
	Czech Rep. + Poland	1200	Germany
	Denmark (east)	550	Germany and Denmark
	Denmark (west)	800	Germany and Denmark
	France	3500	Germany
	Netherlands	3000	Germany
	Poland	1300	Poland
	Sweden	370	Germany and Sweden
	Switzerland	2750	Germany and Switzerland
Germany and Switzerland	Austria	2000//1600	Switzerland//Austria
Greece	Albania	250	Greece
	Albania+Bulgaria+JIEL	600	Greece
	Bulgaria	600	Greece
	Italy	330	Italy and Greece
	JIEL	600	Greece
Hungary	Austria	700	Hungary
	Slovakia	600	Hungary and Slovakia
Italy	Austria + Slovenia	<i>no realistic limit</i>	
	France + Switzerland	<i>no realistic limit</i>	
	Greece	500	Italy and Greece
Moroco	Spain	400	Spain
Netherlands	Belgium	2500	Belgium
	Belgium + Germany	4600	Netherlands
	Germany	5600	Germany
Norway	Denmark (West)	1000	Norway and Denmark
	Sweden	2700	Norway and Sweden
	Finland	70	Norway and Finland
Poland	Czech Rep.	1645//1560	Poland//Czech Rep.
	Slovakia	500	Slovakia
Portugal	Spain	650	Portugal and Spain
Republic of Ireland	United Kingdom	70	RI and UK
Russia	Finland	900(1300*)	Finland (* from 1/1/2003)

These indicative values have been computed by extrapolation from standard situations, in order to evaluate the transfer capacity through a single interface at the same time. Thus these figures should be considered separately and are not cumulative. When the evaluation of a transfer limit requires to use a set of assumption which are too far from usual or foreseeable situation (leading to high inaccuracies), the NTC figure has been replaced by « no realistic limit ».

FROM	TO	MW	VALUE PROVIDED BY
Slovakia	Czech Rep.	<b>1200//600</b>	Slovakia // Czech Rep.
	Hungary	<b>800//950</b>	Slovakia // Hungary
	Poland	<b>500</b>	Slovakia and Poland
Slovenia	Italy	<b>380</b>	Slovenia and Italy
	Austria	<b>800//no realistic limit</b>	Slovenia // Austria
Spain	France	<b>1000</b>	Spain and France
	Morocco	<b>400</b>	Spain
	Portugal	<b>750</b>	Spain and Portugal
Sweden	Germany	<b>460</b>	Sweden and Germany
	Denmark (West)	<b>580</b>	Sweden and Denmark
	Denmark (East)	<b>1300</b>	Sweden and Denmark
	Finland	<b>2050</b>	Sweden and Finland
	Norway	<b>2700</b>	Sweden and Norway
	Poland	<b>600</b>	Sweden and Poland
Switzerland	Austria	<i>no realistic limit</i>	
	France	<i>no realistic limit</i>	
	Germany	<b>2750</b>	Switzerland and Germany
	Italy	<b>3250//2800</b>	Switzerland//Italy
United Kingdom	France	<b>2000</b>	United Kingdom and France
	Republic of Ireland	<b>170</b>	Republic of Ireland

These indicative values have been computed by extrapolation from standard situations, in order to evaluate the transfer capacity through a single interface at the same time. Thus these figures should be considered separately and are not cumulative. When the evaluation of a transfer limit requires to use a set of assumption which are too far from usual or foreseeable situation (leading to high inaccuracies), the NTC figure has been replaced by « no realistic limit ».