

**Indicative values for Net Transfer Capacities (NTC) in Europe
Summer 2002, working day, peak hours
(Non binding values)**

FROM	TO	MW	VALUE PROVIDED BY
Albania	Greece	250	Greece
Albania+Bulgaria+FYROM	Greece	600	Greece
Austria	Germany	1150	Germany
	Italy	200	Italy
	Czech Rep.	390	Czech Rep.
	Italy + Slovenia	650	Austria
	Germany + Switzerland	2900	Austria and Switzerland
	Hungary	300	Hungary
Belgium	France	3100	Belgium
	Netherlands	2200	Belgium
Belgium + Germany	Netherlands	3600	Netherlands
Czech Rep. + Poland	Germany	2350	Germany
Czech Rep.	Germany	2040	Czech Rep.
	Austria	1030	Czech Rep.
	Poland	550	Czech Rep.
	Slovakia	1320	Czech Rep. and Slovakia
Denmark (West)	Germany	1200	Denmark and Germany
Denmark (East)	Germany	550	Denmark and Germany
Denmark (West)	Sweden	610	Denmark and Sweden
Denmark (East)	Sweden	1700	Denmark and Sweden
Denmark (West)	Norway	950	Denmark and Norway
Finland	Sweden	1600	Finland and Sweden
	Norway	100	Finland and Norway
France	United Kingdom	2000	France and United Kingdom
	Belgium	1500	Belgium
	Germany	2350	Germany
	Belgium + Germany	3100	France
	Italy	2310	Italy
	Switzerland + Italy	5500	France
	Spain	1200	France and Spain
France+Switzerland	Italy	4800	France, Italy and Switzerland

These indicative values have been computed by extrapolation from standard situations, in order to evaluate the transfer capacity through a single interface at the same time. Thus these figures should be considered separately and are not cumulative. When the evaluation of a transfer limit requires to use a set of assumption which are too far from usual or foreseeable situation (leading to high inaccuracies), the NTC figure has been replaced by « no realistic limit ».

FROM	TO	MW	VALUE PROVIDED BY
Greece	Albania	250	Greece
	FYROM	600	Greece
	Bulgaria	600	Greece
	Italy	330	Italy and Greece
	Albania+Bulgaria+FYROM	600	Greece
Germany	Austria	1850	Germany
	Belgium + Netherlands	3800	Germany
	Czech Rep. + Poland	2000	Germany
	Czech Rep.	390	Czech. Rep.
	Denmark (east)	550	Germany and Denmark
	Denmark (west)	800	Germany and Denmark
	France	1750	Germany
	Sweden	370	Germany and Sweden
	Switzerland	4400	Germany and Switzerland
Germany and Switzerland	Austria	1800	Austria and Switzerland
Hungary	Austria	700	Hungary
	Slovakia	700//650	Hungary//Slovakia
Italy	Austria + Slovenia	<i>no realistic limit</i>	
	France + Switzerland	<i>no realistic limit</i>	
	Greece	500	Italy
Italy + Slovenia	Austria	<i>no realistic limit</i>	
Moroco	Spain	400	Spain
Netherlands	Belgium	1700	Belgium
	Belgium + Germany	3600	Netherlands
	Germany	1700	Germany
Norway	Denmark (West)	1000	Norway and Denmark
	Sweden	2900	Norway and Sweden
	Finland	70	Norway and Finland
Poland	Czech Rep.	1645	Czech Rep.
Portugal	Spain	550	Portugal and Spain
Republic of Ireland	United Kingdom	70	Republic of Ireland
Russia	Finland	900	Finland

These indicative values have been computed by extrapolation from standard situations, in order to evaluate the transfer capacity through a single interface at the same time. Thus these figures should be considered separately and are not cumulative. When the evaluation of a transfer limit requires to use a set of assumption which are too far from usual or foreseeable situation (leading to high inaccuracies), the NTC figure has been replaced by « no realistic limit ».

FROM	TO	MW	VALUE PROVIDED BY
Slovakia	Czech Rep.	750	Slovakia and Czech Rep.
	Hungary	950//900	Hungary // Slovakia
	Poland	500	Slovakia
Slovenia	Italy	300	Italy
Spain	Portugal	600	Spain and Portugal
	France	700	Spain
	Morocco	400	Spain
Sweden	Germany	460	Sweden and Germany
	Denmark (West)	580	Sweden and Denmark
	Denmark (East)	1300	Sweden and Denmark
	Finland	1900	Sweden and Finland
	Norway	2800	Sweden and Norway
	Poland	600	Sweden
Switzerland	Austria	<i>no realistic limit</i>	
	Germany	2950	Switzerland and Germany
	France	<i>no realistic limit</i>	
	Italy	2900//2490	Switzerland//Italy
United Kingdom	France	2000	United Kingdom and France
	Republic of Ireland	170	Republic of Ireland

These indicative values have been computed by extrapolation from standard situations, in order to evaluate the transfer capacity through a single interface at the same time. Thus these figures should be considered separately and are not cumulative. When the evaluation of a transfer limit requires to use a set of assumption which are too far from usual or foreseeable situation (leading to high inaccuracies), the NTC figure has been replaced by « no realistic limit ».